

## CORRIGENDUM

**Tender Reference number: C-DOTB/TENDER/2026-2027/001 dated 29<sup>th</sup> April 2026.**

Date: 11/05/2026

**Work Description:** Supply, Installation, Testing and Commissioning of Earthing for Electrical Installations at C-DOT Campus.

Pre-Bid Queries	Tender Document Ref.	Tender specification	Corrigendum to tender specification
1.	Technical Specification, Sl.No.4, Page – 10 of tender document	The job includes excavation of hard / soft soil of 3 meters (Depth) and based on the type of earthing (Plate / Pipe earthing). Excavation shall be carried out by means of digging the soil where ever is practicable or by means of auguring the soil.	The job includes excavation of hard / soft soil of 3 meters (Depth) for plate earthing and 4 meters (Depth) for Pipe earthing. Excavation shall be carried out by means of digging the soil where ever is practicable or by means of auguring the soil.
2.	Technical Specification, Sl.No.5, Page – 11 of tender document	Providing and Filling of Salt and Charcoal for each earth Pit	<b>Plate / Pipe Earthing:</b> A homogenous layer of coke/ charcoal and salt shall be cover the Plate / GI pipe as per IS -3043 and CPWD Specification. Refer annexure-1 & 2 in the tender document
3.	Technical Specification, Sl.No.6, Page – 11 of tender document	Earthing System Inspection Chamber	The earth pit chamber shall be a brick masonry chamber constructed at site, as specified in the Technical Specification under Sl. No. 6 7 in the tender document.  The earth pit chamber cover details as specified in the Technical Specification under Sl. No. 7 in the tender document  Please follow as per the tender condition.

All other specifications, terms and conditions remain unchanged.