

S.No.	Reference of Bidding Document				Bidder's Query	EIL / Owner's Reply
	Section	Page No.	Clause No.	Subject		
1	SIB		Cl. No. 6.32		MR item no. 01.013 & 01.015, For maintenance 3 phase (415V 3P + N + E), 125A Power sockets shall be provided so as to ensure complete coverage of the plant through 50-meter radius	Bidder's scope is limited to Socket only
2					please furnish Cable size for 125A. power socket & it's plug	Cable size shall be 3C X 120 sqmm
3					please confirm the type of mounting i.e. suitable for Wall / column / structure OR Pedestal / Self standing type OR Trolley mounted movable type ?	These shall be Wall / column / structure OR Pedestal / Self standing type as per the site requirement. Bidder shall refer to the tender requirements
4					we understood as per Cl. No.: 6.39 of SIB that all ammeters are suitable for 4-20mA signal. Ammeter provided at push-button station shall be 240- degree taut band moving coil type against MR Item No.: 1.43 & 1.44.	Ok. Noted.