



सत्यमेव जयते

भारत सरकार
GOVERNMENT OF INDIA
जल शक्ति मंत्रालय
MINISTRY OF JAL SHAKTI,
जल संसाधन, नदी विकास एवं गंगा संरक्षण विभाग
DEPARTEMENT OF WATER RESOURCES RIVER DEVELOPMENT & GANGA
REJUVENATION
अधिशाली अभियंता का कार्यालय
OFFICE OF THE EXECUTIVE ENGINEER
विद्युत विभाग /ELECTRICAL DIVISION
फरक्का बराज परियोजना
FARAKKA BARRAGE PROJECT

Tender Document

Name of Work: Renovation/ replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP.

NIT No. GM/FBP – 01 of 2026-27

GOVERNMENT OF INDIA: FARAKKA BARRAGE PROJECT
NOTICE INVITING e-TENDER No.GM/FBP – 01 of 2025-26

The Executive Engineer, Electrical Division, Farakka Barrage Project, P.O. Farakka Barrage, Dist. Murshidabad, West Bengal, PIN 742212, Ph: 03485-253291, email id:- eeeld-fbp@gov.in invites on behalf of the President of India online item rate bids **in two bid system** for following work :-

Name of Work: *Renovation/replacement of internal wiring of Control Room Building of Farakka Barrage Project.*

- 1) Estimated Cost put to tender : **Rs. 19,78,174.00**
- 2) Bid Security : **Rs. 39,570.00**
- 3) Time allowed for completion : **4 months**
- 4) Bid submission closing date : 21.05.2026 (1600 hours)

The bid document and other details can be obtained from the website <https://eprocure.gov.in>. All corrigendum shall be issued at the same website.

INDEX

	Description	Page No.
Part-I	Bid Security & Technical Bid	03
	Information & Instructions for bidders	04
	CPWD – 6 for e-tendering	09
	CPWD-8	12
	Schedule-A,B, C , D, E & F	14
	Schedule D 1 - Specification of items	17
	Schedule D 3 – Additional condition of contract	33
	Integrity Pact	36
	Integrity Agreement	38
	Annexure-I	43
	Annexure-II	44
	Annexure-III	45
	Annexure-IV	46-47
	Annexure-V	48
	Annexure-VI	49
	Annexure-VII	50
	Annexure-VIII	51

Part-II	Schedule of Quantities / BoQ
----------------	------------------------------

PART - I

BID SECURITY & TECHNICAL BID

Name of the Work: Renovation/ replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP.

Note

- 1) The bids will only be submitted online after uploading the mandatory scanned documents towards bid security amounting to Rs. **39,570/- drawn** in favour of Sr. Accounts Officer, Pay & Accounts Office, Farakka Barrage Project payable at State Bank of India, Farakka Branch (SBIN0000218) and other documents as specified in the "*INFORMATION AND INSTRUCTIONS FOR BIDDERS FOR e-TENDERING FORMING PART OF BID DOCUMENT AND TO BE POSTED ON WEBSITE*".

ANNEXURE-20A.13.2

(New Annexure as per OM/MAN/224-B)

INFORMATION AND INSTRUCTIONS FOR BIDDERS FOR e-TENDERING FORMING PART OF BID DOCUMENT AND TO BE POSTED ON WEBSITE

(Applicable for inviting bids on 2/3 bid system)

The Executive Engineer, Electrical Division, Farakka Barrage Project, P.O. Farakka Barrage, Dist. Murshidabad, West Bengal, PIN 742212 on behalf of President of India invites online **item rate bids** from experienced, reputed, competent and financially sound agencies fulfilling eligibility and qualification requirements specified in Bidding Documents for the below mentioned work:

Sl. No.	Name of work & location	Estimated cost put to bid (Rs.)	Bid Security (Rs.)	Period of completion	Bid submission closing date & time	Period during which bid security and other documents shall be submitted	Time & date of opening of bid
1	3	4	5	6	7	8	9
01.	Renovation/replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP.	19,78,174/-	39,570/-	120 days	21.05.2026 (1600 hours)	22.05.2026 (upto 1700 hours)	Technical bid on 22.05.2026 (1715 hrs.)

1. Contractors who fulfil the following requirements shall be eligible to apply:
 - a. The bidder should have experience of successfully completed similar works during last seven years ending last day of month previous to the one in which applications are invited either of the following: (Scanned copies of similar nature of works to be uploaded as per the proforma given in **Annexure-III**)
 - i) **Three** similar completed works costing not less than the amount equal to **40** (forty) percent of the estimated cost; or
 - ii) **Two** similar completed works costing not less than the amount equal to **50** (fifty) percent of the estimated cost; or
 - iii) **One** similar completed works costing not less than the amount equal to **80** (eighty) percent of the estimated cost.
 - iv) Similar work shall mean **internal wiring of Buildings of any Central Government/State Government/Public Sector Undertaking Organisation.**
 - v) The certificate of successful completion of work along with the payment certificate should be issued by an officer not below the rank of Executive Engineer/ Project Manager or equivalent.
 - b. The bidder should have an average annual financial turnover of **50%** of estimated cost put tender during the last three years (**2022-23, 2023-24, 2024-25**) (Scanned copy of Certificate from CA with UDIN number mandatorily to be uploaded).

- c. Bidder should also submit the 'Net Worth Certificate' from CA (with UDIN number mandatorily) in prescribed format as per proforma given in **Annexure - IV**
- d. The bidder should not have incurred any loss in more than two years during the last five years ending **31st March, 2025**. (An affidavit in this regard should be submitted)
- e. The bidder should have a bank solvency minimum **40% (forty percent)** of estimated cost put to tender **not older than 6 months** from the date of publishing of tender (Scanned copy of original solvency as per the proforma given in **Annexure - V** clearly mentioning date of issue to be uploaded).
- f. The bidder should possess a valid **Electrical Contractors License**.

2. Bidder must:

- (a) Not be insolvent, in receivership, bankrupt or being wound up, not have its affairs administered by a court or a judicial officer, not have its business activities suspended and must not be the subject to legal proceedings for any of aforesaid reasons.
- (b) (Including their affiliates or subsidiaries or contractors / sub-contractors for any part of the contract):
 - (i) Not stand declared ineligible / blacklisted / banned / debarred by the procuring organization or its Ministry / department from participation in its tender process; and / or
 - (ii) Not be convicted (within three years preceding the last date of bid submission) or stand declared ineligible / suspended / blacklisted / banned / debarred by appropriate agencies of Government of India from participation in tender processes of all of its entitles, for:
 - ❖ Offences involving moral turpitude in business deadlines under the Prevention of Corruption Act, 1988 or any other law; and / or
 - ❖ Offences under the Indian Penal Code or any other law for causing any loss of life / limbs / property or endangering public health during the execution of a public procurement contract and / or
 - ❖ Suspected to be or doubtful loyalty to the country or a national security risk as determined by appropriate agencies of the Government of India.
 - (iii) Not have changed its name or created a new "Allied Firm", consequent to having declared ineligible / suspended / blacklisted / banned / debarred as above.
 - (iv) Not have an association (as a bidder / partner / director / employee in any capacity):
 - ❖ Of any retired Manager (of Gazetted rank) or any retired Gazetted Officer of the Central or State Government or its Public Sector Undertakings if such a retired person has not completed the cooling-off period of one year after his retirement. However, this shall not apply if such Managers / Officers have obtained a waiver of the cooling-off period from their erstwhile organization.
 - ❖ Of the near relations of executives of procuring entity involved in this tender process.
- (c) Not have a conflict of interest, which substantially affects fair competition. The prices quoted should be competitive and without adopting any unfair / unethical / anti-competitive means. No attempt should be made to induce any other bidder to submit or not to submit an offer for restricting competition.

3. The intending bidder must read the terms & conditions of **CPWD-6 FOR e-TENDERING** carefully. He should only submit his bid if he considers himself eligible and he is in possession of all the documents required.
4. Bidders from specified countries having land borders with India (but not in development partnership with India) shall be eligible subject to certain conditions as per the restriction under Rule 144 (xi) of the General Financial Rules (GFRs), 2017.

A certificate regarding the compliance of the above in the letter head of the bidder duly signed and stamped by the authorized representative of the bidder as per **Annexure – VI** to be submitted along with the tender. If the certificate submitted by the bidder whose bid is accepted is found to be false, this would be a ground for immediate termination and further legal action in accordance with law.

"We have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India; we certify that (Name of firm / bidder) is not from such a country or, if from such a country, has been registered with the Competent Authority. We hereby certify that (Name of Firm / Bidder) fulfils all requirements in this regard and is eligible to be considered".

(Where applicable, evidence of valid registration by the Competent Authority shall be attached).

5. The procuring entity reserves its right to grant preferences to eligible bidders under various Government Policies (policies relating to Make in India; SME; Start-ups etc.).
6. Information and instructions for bidders posted on website shall form part of the bid document.
7. The bid document consisting of specifications, the schedule of quantities of various types of items to be executed and the set of terms & conditions of the contract to be complied with and other necessary documents can be seen / downloaded from website <https://eprocure.gov.in> free of cost.
8. But the bid can only be submitted after uploading the mandatory scanned documents such as Bid Security drawn in favour of Sr. Accounts Officer, Pay & Accounts Office, Farakka Barrage Project payable at State Bank of India, Farakka Branch (IFSC Code SBIN0000218) and other documents as specified. The mode of payment of cost of bid/ bid security and performance is given below:
 - a. The bid security may be accepted in the form of Insurance Surety Bonds, account payee Demand Draft, Fixed Deposit Receipt, Banker's Cheque or Bank Guarantee (as per proforma given as **Annex-I**) from any of the Commercial Banks in an acceptable form.
 - b. Performance Security may be furnished in the form of Insurance Surety Bonds, account payment Demand Draft, Fixed Deposit Receipt from a Commercial Bank, Bank Guarantee from a Commercial Bank in an acceptable form.

Note: *In case of contractor who is / are claiming relaxation in submission of bid security / EMD in such cases they have to submit the Bid Security Declaration form in the prescribed format attached as **Annex-VII**. However, the bidder(s) registered with MSME under NIC 2008 **Code No.- 43211 Installation of electrical wiring and fittings** can only claim relaxation in bid security / EMD.*

9. Those contractors not registered on the website mentioned above, are required to get registered beforehand. If needed, they may take training on online bidding process as per details available on the website.

10. The intending bidder must have valid Class-III digital signature to submit the bid.
11. The bidder can upload documents in the **JPG** format or **PDF** format.
12. **Certificate of Financial Turnover:** At the time of submission of bid, bidder may upload Affidavit / Certificate from CA mentioning Financial Turnover of last 3 years or for the period as specified in the bid document and further details, if required, may be asked from the bidder after opening of technical bids. There is no need to upload entire voluminous balance sheet.
13. Bidder must ensure to quote rate of each item. If any cell is left blank and no rate is quoted by the bidder, rate of such item shall be treated as "0" (Zero).
14. The Technical Bid shall be opened first on due date and time as mentioned in Para 16 below. The financial bids of bidders qualifying the technical bid shall be opened subsequently.
15. No Pre Bid meeting shall be held for intending bidders.
16. The department reserves the right to reject any prospective application without assigning any reason and to restrict the list of qualified bidders to any number deemed suitable by it, if too many bids are received satisfying the laid down criterion.
17. The Farakka Barrage Project(FBP) shall not be held liable for any delays due to system failure beyond its control. Even though the system will attempt to notify the bidders of any bid updates, the FBP shall not be liable for any information not received by the bidder. It is the bidder's responsibility to verify the website for the latest information related to the tender / bid.
18. It is mandatory for all prospective bidders to undertake a site visit before submitting their bids. The purpose of the site visit is to provide the bidders with a comprehensive understanding of the site requirement and the conditions that may affect the execution of the service. Failure to undertake a site visit under the supervision of FBP site engineer and uploading the site / plant visit report as per proforma given as **Annex-VIII**, duly signed by the site engineer of the work / representative of FBP, duly assigned by EIC, may lead to rejection of bid(s). Bidders shall request for arrangement of site visit physically or through email request shall reach before 2 (two) days of last date of submission of bid. Beyond this, no request shall be entertained. Further, on prescribed visit date as intimated by the office of Executive Engineer, Electrical Division, physically and submit the same after site visit, duly signed as mentioned above.
19. **Submission of original documents:** - The bidder are required to submit following documents in original to the Executive Engineer, Electrical Division, Farakka Barrage Project, P.O. Farakka Barrage, Dist. Murshidabad, West Bengal, PIN 742212 or to the office of Superintending Engineer, Circle-III, Farakka Barrage Project upto specified date and time. If the office happens to be closed on the last date of receipt of original documents, the same will be received on the next working day till the same time and venue.
 - a. Document towards Bid Security as mentioned at clause No. 8(a) in case not claiming relaxation for Bid Security.

In case of failing of submission of above before deadline, bidder will be declared non-responsive.
20. Summary of important dates is as below:
 - (i) Document download / sale start date : 14.05.2026 (0900 hours)

- (ii) Pre bid meeting date : Not Applicable
- (ii) Bid submission start date : 14.05.2026 (0900 hours)
- (iii) Bid submission closing date : 21.05.2026 (upto 1600 hours)
- (iv) Technical Bid opening date : 22.05.2026 (1715 hours)

21. List of documents to be scanned and uploaded in CPPP portal within the period of bid submission failing which the bidder will not be eligible to participate in the bid:

- (i) Proof of document for submission of bid security.
- (ii) Certificate of past work experience as per proforma as Annex-III.
- (iii) Certificate of Financial Turnover from registered Chartered Accountant having valid UDIN.
- (iv) Bank Solvency Certificate not older than 6 months from the date of publishing of tender (scanned from original copy).
- (v) Any other document as specified in the press notice/ tender Document/ other related document.
- (vi) Affidavit regarding correctness of bid, criteria for fulfilling eligibility and authenticity other documents to be submitted along with the bid.
- (vii) Affidavit regarding No loss in more than two years during the last five years ending 31st March, 2025.
- (viii) PAN Card, Trade License, GST Registration Certificate, EPFO Registration Certificate with EPFO code, ESIC Certificate.
- (ix) Electrical Contractors License.
- (x) Integrity pact.
- (xi) Self-certificate under Rule 144 (xi) of the General Financial Rules (GFRs), 2017, given in Annexure VI.
- (xii) Bid Security Declaration Form in case of relaxation for Bid Security claimed is sought as per proforma given as Annexure VII.
- (xiii) Net Worth Certificate from CA having valid UDIN as per proforma given in Annexure IV.
- (xiv) Site / plant visit report as per proforma given as Annexure-VIII.

Executive Engineer
Electrical Division,
Farakka Barrage Project

CPWD-6 FOR e-TENDERING

1. The Executive Engineer, Electrical Division, Farakka Barrage Project, P.O. Farakka Barrage, Dist. Murshidabad, West Bengal, PIN 742212 on behalf of President of India invites online item rate bids from experienced, reputed, competent and financial sound Indian Contractors/Companies/Firms/Joint Ventures fulfilling eligibility and qualification requirements specified in the Bidding document in two bid system for the work, **"Renovation/replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP"**.
 - 1.1 The work is Estimated to Cost Rs. 19,78,174.00 (Rupees Nineteen lakh Seventy Eight thousand One Hundred Seventy Four) only. This estimate, however, is given merely as a rough guide.
 - 1.2 Intending bidder is eligible to submit the bid provided he has definite proof from the appropriate authority which shall be to the satisfaction of the competent authority of having satisfactory completed or substantially completed works of magnitude as specified below:
 - i) Three similar works each of value not less than the amount equal to **40%** of the Estimated cost put to tender (ECPT) or two similar work each of value not less than the amount equal to **50%** of ECPT or one similar work of value not less than the amount equal to **80%** of the ECPT(rounded off to a nearest convenient full) during last 7 years ending last day of month previous to the one in which applications are invited. **Similar work shall means internal wiring of Buildings of any Central Government/State Government/Public Sector Undertaking Organisation.**

The certificate for successful completion of work along with the payment certificate should be issued by an officer not below the rank of Executive Engineer/ Project Manager or equivalent.
2. Agreement shall be drawn with the successful bidder on prescribed **Form No. CPWD 7/8** or other standard Form as mentioned which is available as a Govt. of India Publication and also available on website www.cpwd.gov.in. Bidder shall quote his rates as per various terms and conditions of the said form which will form part of the agreement. The entire bidding document and all the relevant correspondences/ corrigendum issued will also be the part of the Agreement.
3. The time allowed for carrying out the work will be **6 (six) months** from the date of start of work. The date of start of work will be reckoned from **7th** day from the date of issue of work order.
4. The tender document consisting of drawing, plans, specifications, the schedule of quantities of various types of items to be executed and the set of terms and conditions of the contract to be complied with and other necessary documents except "Standard General Conditions of Contract form" can be seen & download from website <https://eprocure.gov.in> free of cost.
5. Interested bidders who wish to participate in the bid have to make payment towards bid security on detailed above.

6. Copy of certificate of work experience along with the payment certificate and other documents as specified in the tender document for eligibility shall be scanned and uploaded to the e-tendering website within the period of tender submission.
7. Online bid documents submitted by intending bidders shall be opened only of those bidders whose bid security and other documents are found in order. The Price bid submitted shall be opened in respect of eligible bidders fulfilling the eligibility criteria. The bid submitted shall become invalid if-
 - i) The bidder is found ineligible.
 - ii) The bidder does not upload all the documents (including PAN / GST etc.) as stipulated in the bid document.
 - iii) If any discrepancy is noticed between the documents as uploaded at the time of submission of bid and hard copies as submitted physically by the lowest bidder in the office of tender opening authority.
8. Various taxes on material, Royalty, Purchase Tax, Turnover Tax, Excise Duty, Service Tax, Work Contract Tax, entry tax or any other tax on materials/work, as applicable, shall be paid by the contractor himself. **The contractor shall quote his rates considering all such taxes but excluding GST.**
9. The bidder, whose tender is accepted, will be required to furnish Performance Guarantee of 5% (five Percent) of the tendered amount within the period specified in the bid document / other related document. The mode of payment has been given in the "Information & Instruction to the Bidder's" above. In case the contractor fails to deposit the said performance guarantee within the specified period including the extended period if any, the bid security deposited by the bidder shall be forfeited automatically without any notice to the bidder.
10. Intending bidders are advised to inspect and examine the site and its surroundings and satisfy themselves before submitting their bids as to the, the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their bid. A bidder shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charge consequent on any misunderstanding or otherwise shall be allowed. The bidder shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, water, electricity access, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a bid by a bidder implies that he has read this notice and all other contract documents and has made himself aware of the scope and specifications of the work to be done and of conditions and rates at which stores, tools and plant, etc. will be issued to him by the Government and local conditions and other factors having a bearing on the execution of the work.
11. The competent authority on behalf of the President of India does not bind himself to accept the lowest or any other bid and reserves to him the authority to reject any or all the tenders received without the assignment of any reason. All bids in which any of the prescribed condition is not fulfilled or any condition including that of conditional rebate is put forth by the bidder shall be summarily rejected.
12. Canvassing whether directly or indirectly, in connection with bidders is strictly prohibited and the bids submitted by the bidders who resort to canvassing will be liable for rejection.

13. The competent authority on behalf of President of India reserves to himself the right of accepting the whole or any part of the bid and the bidder shall be bound to perform the same at the rate quoted.
14. The contractor shall not be permitted to bid for works in the FBP if his near relative is posted as a Divisional Accountant or as an officer in any capacity between the grades of General Manager and Junior Engineer (both inclusive). He shall also intimate the names of persons who are working with him in any capacity or are subsequently employed by him and who are near relatives to any gazetted officer in the FBP or in the Ministry of JAL Shakti, Department of Water Resources, River Development & Ganga Rejuvenation. Any breach of these conditions by the contractor would render ineligible for award of work / continuing with the work.
15. No Engineer of gazetted rank or other Gazetted Officer employed in Engineering or Administrative duties in an Engineering Department of the Government of India is allowed to work as a contractor for a period of one year after his retirement from Government service, without the prior permission of the Government of India in writing. This contract is liable to be cancelled if either the contractor or any of his employees is found any time to be such a person who had not obtained the permission of the Government of India as aforesaid before submission of the bid or engagement in the contractor's service.
16. The bid for the works shall remain open for acceptance for a period of 90(ninety) days from the date of opening of financial bid in case bids are invited on 2 bid systems. If any bidder withdraws his bid before the said period or issue of letter of acceptance, whichever is earlier, or makes any modifications in the terms and conditions of the bid which are not acceptable to the department, then the Government shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said bid security as aforesaid. Further the bidder shall not be allowed to participate in the re-bidding process of the work.
17. This notice inviting bid shall form a part of the contract document. The successful bidder/ contractor, on acceptance of his bid by the Accepting Authority shall within 15 days from the stipulated date of start of the work, sign the contract consisting of:-
 - a) The Notice Inviting bid, all the documents including additional conditions, specifications and drawings, if any, forming part of the bid as uploaded at the time of invitation of bid and the rates quoted online at the time of submission of the bid and acceptance thereof together with any correspondence leading thereto.
 - b) Standard C.P.W.D. Form 7/8 and other standard forms mentioned which is part of uploaded tender document.

Executive Engineer,
Electrical Division,
Farakka Barrage Project,
For & on behalf of President of India

GOVERNMENT OF INDIA
FARAKKA BARRAGE PROJECT

STATE : West Bengal

DIVISION: ELECTRICAL DIVISION, FBP

CIRCLE : Circle-I, Farakka Barrage Project

SUB-DIVISION : Outer Sub-Division

Item Rate Tender & Contract for Works

Tender for the work: Renovation/ replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP.

Bids to be submitted online by 1600 hours on 21.05.2026 at website <https://eprocure.gov.in>.

- (i) Technical bid to be opened online at 1715 hours on 22.05.2026 by authorized officers of Farakka Barrage Project in presence of the Executive Engineer, Electrical Division, Farakka Barrage Project, P.O. Farakka Barrage, Dist. Murshidabad, West Bengal, PIN 742212.
- (ii) Summary of important dates is given in Sl. No. 21 of Annexure-20A.13.2 under "Information and instructions for bidders for e-tendering forming part of bid document and to be posted on website.

TENDER

I/We have read and examined the notice inviting tender, schedule A, B, C, D, E & F. Specifications applicable, Drawings, General Rules and Directions, Conditions of Contract, clauses of contract, Special conditions, Schedule of Rate & other documents and Rules referred to in the conditions of contract and all other contents in the tender document for the work.

I/We hereby tender for the execution of the work specified for the President of India within the time specified in Schedule 'F', viz., schedule of quantities and in accordance in all respects with the specifications, drawings and instructions in writing referred to in Rule-1 of General Rules and Directions and in clause 11 of the Conditions of contract and with such materials as are provided for, by, and in respects in accordance with, such conditions so far as applicable.

We agree to keep the tender open for **90** (ninety) days from the due date of its opening of financial bid and not to make any modifications in its terms & conditions.

A sum of Rs. 39,570.00 (Rupees Thirty Nine Thousand Five Hundred Seventy only) is hereby deposited in the prescribed form mentioned earlier as bid security. I/we agree that if I/We fail to furnish the prescribed Performance Security within the prescribed period to the President of India or his successors in office shall without prejudice to any other right or remedy, be at liberty to forfeit the said bid security absolutely. Further, If I/ We fail to commence work as specified, I/We agree that President of India or his successors in office shall without prejudice to any other right or remedy available in law, be at liberty to forfeit the said bid security and Performance Security absolutely, otherwise the said bid security shall be retained by him towards security deposit to execute all the works referred to in the tender documents upon the terms & conditions contained or referred to therein and to carry out such deviations as may be ordered, up to maximum of the

percentage mentioned in schedule 'F' and those in excess of that limit at the rates to be determined in accordance with the provision contained in Clause 12.2 and 12.3 of the tender form. Further, I/we agree that in case of forfeiture of bid security or both bid security & Performance Security as aforesaid, I/we shall be debarred for participation in the re-tendering process of the work.

I/We undertake and confirm that eligible similar works(s) has/have not been got executed through another contractor on back to back basis. Further that, if such a violation comes to the notice of Department, then I/we shall be debarred for tendering in FBP in future forever. Also, if such a violation comes to the notice of Department before start of work, the Engineer-in-Charge shall be free to forfeit entire amount of bid security / Performance security.

I/We hereby declare that I/We shall treat the tender documents, drawings and other records connected with the work as secret/confidential documents and shall not communicate information / derived there from to any person other than a person to whom I/We, am/are authorized to communicate the same or use the information in any manner prejudicial to the safety of the state.

Date : _____ Signature of the : _____
 Contractor**

Postal Address ** : _____

Telephone No. ** : _____
 Fax No. ** : _____
 e-mail ID ** : _____

Witness : _____ Fax No. ** : _____
 _____ e-mail ID ** : _____

Address : _____

Occupation : _____

** to be filled in by contractor

ACCEPTANCE

The above tender (as modified by you as provided in the letters mentioned hereunder) is accepted by me for an on behalf of the President of India for a sum of Rs. _____ (Rupees_____).

The letters referred to below shall form part of this contract agreement:-

- (a)
- (b)
- (c)

For & on behalf of President of India

Signature _____

Executive Engineer,
 Electrical Division, Farakka Barrage Project

PROFORMA OF SCHEDULES

SCHEDULE 'A'

Schedule of quantities

As given in schedule of work/ BoQ (Part II)

SCHEDULE - 'B'

Schedule of materials to be issued to the contractor: **Not Applicable**

SCHEDULE - 'C'

Tools and plants to be hired to the contractor: **Not Applicable**

SCHEDULE - 'D'

Extra schedule for specific requirements/ documents for the work, if any: **NIL**

Technical specifications and additional conditions are attached at page no. **17 to 34**

SCHEDULE - 'E'

Reference to General Conditions of contract

Name of work: *Renovation/replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP.*

Estimated cost of work	Rs. 19,78,174.00
i) Bid Security	Rs. 39,570.00
ii) Performance Security	5% of tendered value of work.

SCHEDULE - 'F'

Reference to General Conditions of contract

Officer inviting tender: : Executive Engineer, Electrical Division, Farakka Barrage Project, P.O. Farakka Barrage, Dist. Murshidabad, West Bengal, PIN 742212, Ph: 03485-253291. email id– eeeld-fbp@gov.in

Maximum %age for quantity of items of work to be executed beyond which rates are to be determined in accordance with clauses 12.2 and 12.3 : See below

Definitions:

2(v) Engineer-In-Charge :Executive Engineer, Electrical Division Farakka Barrage Project, P.O. Farakka Barrage, Dist. Murshidabad, West Bengal, PIN 742212

2(viii) Accepting Authority General Manager, Farakka Barrage Project

- 2(x) Percentage on cost of materials and labour to cover all overheads and profits 15 %
- 2(xi) Standard Schedule of Rates CPWD DSR (E&M)-2022, Schedule of Rates of West Bengal PWD (Electrical)-2017, Rate approved by the Rate Committee.
- 2(xii) Department Farakka Barrage Project
- 9(ii) Standard CPWD contract Form CPWD form 7/8 as modified & corrected up to latest amendments.

Clause 1

- i) Time allowed for submission of Performance Guarantee : 07 (Seven) days from the date of issue of letter of acceptance, in days
- ii) Maximum allowable extension with the approval of tender accepting authority with late fee @ 0.1% per day of the performance security amount beyond the period provided in (i) above in days : 07 (Seven) days

Clause 2

Authority for fixing compensation under clause -2 : Superintending Engineer, Circle -I, FBP

Clause 2A

Whether Clause 2A shall be applicable: No

Clause 5

Number of days from the date of issue of letter of acceptance for reckoning date of start : 7 (Seven) days

Mile stone(s) as per table given below:

Table of Mile Stone(s)

Sl. No.	Description of Mile Stone (Physical)	Time Allowed in days (from date of start)	Amount to be withheld in case of non-achievement of milestone
NA.....

OR

Sl. No.	Physical Progress	Time Allowed (from date of start)	Amount to be withheld in case of non-achievement of milestone
1.	1/8 th (of whole work)	1/4 th (of whole work)	1% of the tendered value of work will be withheld for failure of each milestone.
2.	3/8 th (of whole work)	1/2 th (of whole work)	
3.	3/4 th (of whole work)	3/4 th (of whole work)	
4.	Full	Full	

Time allowed for execution of work : 6 months

Authority to give fair & reasonable extension of time for completion of work : Executive Engineer, Electrical Division, FBP

Clause 7

Gross work to be done together with net payment/ adjustment of advances for material collected, if any, since the last such payment for being eligible to interim payment : Not applicable

Clause-8 A

Contractor to keep Site Clean. : **Applicable**

Clause- 10 A

Materials to be provided by the contractor : **Applicable (As per direction of EIC)**

Clause 10B (ii)

Whether Clause 10 B (ii) shall be applicable : Not Applicable

Clause 10 C A : Stands deleted

Clause 10 CC : Stands deleted

Clause 11

Specifications to be followed for execution of work : **As per direction of the Engineer-in-charge.**

Clause 12

12.2 & 12.3 Deviation Limit beyond which clauses 12.2 & 12.3 shall apply for the work : **25%**

12.5 Deviation Limit beyond which clauses 12.2 & 12.3 shall apply for foundation work : Not applicable

Clause 16

Competent Authority for deciding reduced rates : General Manager, Farakka Barrage Project, Farakka, Dist:- Murshidabad (WB)

Clause 36 (i): Not Applicable

20. Clause 42 : Not Applicable

Executive Engineer
Electrical Division,
Farakka Barrage Project

SCHEDULE – D-1

SPECIFICATION OF ITEMS AND MODE OF PAYMENT

SPECIFICATIONS OF ITEMS

Scope of Work

The works are to be carried out as per technical specifications of each item and as per the directions of Engineer-In-Charge as per actual site conditions strictly within the specified time frame. All the items/materials are to be ISI approved, reputed make and have to be got approved by EIC before fixing. The works are to be carried out as per the specification and to the satisfaction of EIC or his authorized representative. The specifications of the works are detailed as under:-

Item No-1 Supplying and fixing 415V, TPN SFU with sheet steel enclosure on flat iron/angle iron frame on wall with nuts bolts etc incl. S & F 3 nos. DIN type HRC fuse as per rating on angle iron frame 315/320 A Havells.

This item involves supplying and fixing 415V, TPN SFU with sheet steel enclosure on flat iron/angle iron frame on wall with nuts bolts etc incl. S & F 3 nos. DIN type HRC fuse as per rating on Angle iron frame of rating 315/320 A.

The Switch Fuse unit conforming to **IS code 60947-3 :1999 latest**. Surface mounted type of enclosure, shall be fabricated from 2mm thick CRCA sheet, knock outs at Top and Bottom for cable entry, mounting holes for fixing the enclosure, door interlocking facility, IP 54 Degree of protection, minimum 1000(no. of cycles) mechanical endurance. HRC fuse link type fuse, silver plated materials of terminal, contactor shall be electrolytic copper. Switch fuse units shall be enclosed with the doors. Complete set of test certificates need to be submitted.

315/320 Amp Main Switch- It will be used as Incoming Main Switch in the panel where Incoming cable from Transformer will connect to it and further it will join to Main Busbar of 315/320 Amp. 1 no for mahapagla regulator and 02 no for Bansloi regulator. Cable from the Bus bus bar of 315/320 Amp will connect to these Main switch.

Agency has to provide minimum 1 year of warranty for this item. The Main Switch will be installed as per the location decided by the Engineer-In-Charge. The item includes all materials, labour, tools & tackles etc. as required. The height of main switch should be 1.5 meter from the ground level. The Main switch shall have to be got approved by the EIC. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each Main Switch supplied and fixed satisfactorily.

Item No-2 Supplying & fixing sheet metal (16 SWG) Iron Clad Bus-bar chambers on angle iron frame on wall, incl. earthing attachment and painting as required 4 bars, 415 V, 315 A, Dimension of Cu. Bars [85mm long] - 4 x 50x5mm, Dimension of Sheet Metal Box- 500x150mm.

This item include supplying & fixing sheet metal (16 SWG) Iron Clad Busbar chambers on angle iron frame on wall, incl. earthing attachment and painting as required and as per rating. The bus bar shall be made of copper conforming to **IS code 613:2000**. The rating of bus bar shall be 315 A.

The cross section of neutral bus bar must be same as that of the phase bus bars. Each bus bar shall be suitably insulated with PVC sleeves/tapes. Bus Bar support insulators shall be class F insulators made of non- hygroscopic, non-combustible, track resistant and high strength FRP/SMC/ DMC material, and shall be of suitable size and spacing to with-stand the dynamic stresses due to short circuit currents. Proper spacing between two insulator shall be provided. The minimum clearance between phase to phase and phase to earth bus bar shall be 32 mm and 26 mm respectively. Bus bar and main connection shall be marked by the colour. The Busbar chambers should be enclosed in sheet metal of 16 SWG of dimension 500 X 150 mm and fixed on a angle iron frame on wall. The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The height of Bus bar should be 1.5 meter from the ground level. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for per meter set of 4 bus bar of 315 A rating supplied and fixed satisfactorily.

Item No-3 Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator), 8 way , Double door.

This item include supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections including earthing etc. as required. (But without MCB/RCCB/Isolator) 8 way , Double door. Total 3 nos MCBDB will be installed at the Mahapagla and Basnsloi regulator. 1 no for Mahapagla regulator and 2 nos for Bansloi regulator.

The material of MCB DB Box shall be of Mild steel- properly pre-treated and stove enamelled / powder coated. 1.2 mm (MS Sheet) thickness, IP 43 Degree of Protection. MCB DB Box conforming to **IS code 13032:1991 latest**. Manufacturer test certificates need to be submitted. The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The height of SPN MCB DB Box should be 1.5 meter from the ground level. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each MCB DB Box supplied and fixed satisfactorily.

Item No-4 Supplying and fixing 5 A to 32 A rating, 240/415 V, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required Single Pole.

The item involves supplying and fixing 5 A to 32 A rating, 240/415 V, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the

existing MCB DB complete with connections, testing and commissioning conforming to **IS 60898 : PART 1:2015 latest**. Complete set of test certificates need to be submitted. The MCB's should be of reputed brand (ISI marked) as given in estimate and shall have to be got approved by the Engineer-In-Charge before fixing. Agency has to provide minimum 1 year of warranty for this item. Manufacturer test certificates need to be submitted. If any fault comes proper replacement must be provided at minimum time. The MCB should be fixed in slot provided in the MCB DB Box with proper wiring connection. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 5- 32 A single pole and double pole MCB supplied and fixed satisfactorily.

Item No-5 Supplying and fixing following rating, double pole, 240 V, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required 40 A.

The item involves Supplying and fixing following rating, double pole, 240 V, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required 40 A. Complete set of test certificates need to be submitted. The Isolator should be of reputed brand (ISI marked) as given in estimate and shall have to be got approved by the Engineer-In-Charge before fixing. Agency has to Provide minimum 1 year of warranty for this item. Manufacturer test certificates need to be submitted. If any fault comes proper replacement must be provided at minimum time. The Isolator should be fixed in slot provided in the MCB DB Box with proper wiring connection. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 40 A Isolator supplied and fixed satisfactorily.

Item No-6 Supplying and fixing PVC casing-capping [Precision Make] on wall or ceiling, incl. necy. PVC fittings etc. and mending good damages to building works, 25X10 mm size.

The item involves supplying and fixing PVC casing-capping [Precision Make] on wall or ceiling, incl. necy. PVC fittings etc. and mending good damages to building works, 25X10 mm size. The Casing capping should be of reputed brand (ISI marked) as given in estimate and shall have to be got approved by the Engineer-In-Charge before fixing. PVC casing capping shall be complying to IS code **9537(part-3):183**. The casing capping shall be marked with Manufacturer's name or trade-mark, Nominal size of the conduits and ISI mark. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for running meter of 25 X 10 mm size PVC casing capping supplied and fixed satisfactorily.

Item No-7 Supplying and drawing following sizes of FRLS/HFFR PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required.

- 7. 1 3 x 6 sq. mm**
- 7. 2 3 x 4 sq. mm**
- 7. 3 3 x 2.5 sq. mm**
- 7. 4 2 x 2.5 sq. mm**
- 7. 5 3 X 1.5 sq. mm**

This item includes wiring for circuit/ submain wiring along with earth wire by supplying and drawing the FRLS PVC insulated copper conductor, single core cable of specified size in the existing PVC casing capping as required.

PVC insulated unsheathed and sheathed cables/ cords with rigid and flexible conductor for rated voltages up to and including 450/750 V complying to **IS 694:2010(latest)**. The wire shall be composed of annealed, bare or tinned high conductivity copper wire complying to **IS 8130:2013 (latest)**. PVC insulation of electric wires as per **IS 5831:1984**. There shall be marking on the wire at every meter such as ISI mark, manufacturer name, month & year of manufacture, wire voltage grade FRLSH & type. Manufacturer test certificates shall have to be submitted by the agency.

The wire shall be drawn in suitable size of medium class PVC casing capping on the wall. PVC casing capping shall be complying to IS code **9537(part-3):183**. The casing capping shall be marked with Manufacturer's name or trade-mark, Nominal size of the conduits and ISI mark.

The wire make shall have to be got approved by the Engineer-in-Charge before fixing. No joints in wiring will be permitted anywhere except in the bus bar, MCB DB Box, switchboard. The wiring throughout in the installation such that there is no break in the neutral wire except in the form of linked switchgear. The item includes all materials, labour, tools & tackles etc. as required.

The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

Following colour code shall be followed in the wiring:

Phase : Red/Yellow/Blue (3 phase), Live : Red (1 phase) , Neutral : Black, Earth : Green.

- i) 3 X 6 sq. mm

This wire is to be drawn from the VTPN Box/ Main switch in to the Lightning and power MCBDB in each floor.

- ii) 3 X 4 sq. mm

This wire is to be drawn from the power circuit MCBDB to the AC power point and power socket.

- iii) 3 X 2.5 sq. mm

This wire is to be drawn from the lightning point MCBDB to the lightning point switch board and computer board.

- iv) 3 x 1.5 sq. mm

This wire is to be drawn from the Junction board to the intermediate switch socket board point and as a inverter wiring.

The measurement and payment shall be made for supplying and drawing the FRLS PVC insulated copper conductor, single core cable of specified size in existing PVC casing capping satisfactorily.

Item No-8 Distribution wiring in 1.1 KV grade 2x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in suitable size PVC casing-capping (Precision make) with 1x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, incl. necy. PVC clips, fittings etc. to light/fan/call bell point with piano key type switch (Anchor make) fixed on sheet steel fabricated switch board with Perspex/bakelite top cover on wall incl. necy. connections and making earthing attachment and mending good damages to building works. [PVC casing-capping and Switch board both on surface].

12.01 Average run 5 mtr

12.02 Average run 8 mtr

The item involves distribution wiring in 1.1 KV grade 2x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire (Brand approved by EIC) in suitable size PVC casing-capping (Precision make) with 1x22/0.3 (1.5 sqmm) single core stranded 'FR' PVC insulated & unsheathed copper wire for ECC, incl. necy. PVC clips, fittings etc. to light/fan/call bell point with piano key type switch (Anchor make) fixed on sheet steel fabricated switch board with Perspex/bakelite top cover on wall incl. necy. connections and making earthing attachment and mending good damages to building works. [PVC casing-capping and Switch board both on surface]. PVC insulated unsheathed and sheathed cables/ cords with rigid and flexible conductor for rated voltages up to and including 450/750 V conforming to IS code 694:2010(latest). The wire shall be composed of annealed, bare or tinned high conductivity copper wire conforming to IS code 8130:2013 (latest). PVC insulation & sheath of electric wire as per IS 5831:1984. There shall be marking on the wire at every meter such as ISI mark, manufacturer name, month & year of manufacture, wire voltage grade FRLSH & type. Manufacturer test certificates shall have to be submitted by the agency. The item includes all materials, labour, tools & tackles etc. as required.

The point (other than socket outlet point) shall include all work necessary in complete wiring to the following outlets from the controlling switch.

Ceiling rose or connector (in the case of points for ceiling/ exhaust fan points, prewired light fittings, and call bells). Ceiling rose shall be as per IS code 371 :1999.

Lamp holder (in the case of goose neck type wall brackets, batten holder) shall be as per IS code 1258:2005.

GI Box should be made of 18 gauge, Mild steel of suitable size.

Frame plate of the switch board shall be made of Polycarbonate Electrical Grade of 2.5 mm thick and marked with manufacturers name / trade mark.

Wiring shall be done only by the looping system. Phase / live wires shall be looped at the switch board. Neutral wire/ earth wire looping for the 1st point shall be done at the switch board and neutral/ earth looping of subsequent points will be made from the point outlets.

Following colour code shall be followed in the wiring:

Phase/ Live : Red, Neutral : Black, Earth : Green.

Point wiring will have Average run of 5 mtr and 8 mtr.

The wire make shall have to be got approved by the Engineer-in-Charge before fixing. No joints in wiring will be permitted anywhere except in the switchboard. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for number of point fixed satisfactorily.

Item No-9 Supplying and fixing metal box of following sizes (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including painting etc. as required. 200 mm X 250 mm X 100 mm deep.

This items involves supplying and fixing metal box of following sizes (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including painting etc. as required.

- i) 200 mm X 250 mm X 100 mm deep:- This Switch board will be installed as computer switch board as per the location decided by the Engineer In charge in which there will be 3 nos of 5 Amp switch socket and 2 nos 15/ 16 Amp switch socket will be fixed.

Switch board should be GI Box made up of 18 gauge, Mild steel of suitable size.

Frame plate of the switch board shall be made of Polycarbonate Electrical Grade of 2.5 mm thick and marked with manufacturers name / trade mark.

The height of switch board should be 1.2 meter from the ground level. Proper spacing must be provided between switch and socket. The Switch board and its frame plate should be ISI marked. All the materials have to be got approved by the Engineer-in-charge before fixing. Agency has to provide minimum 1 year of warranty for this item. If any fault comes proper replacement must be provided in minimum time. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each Switch board along with its suitable size frame plate supplied and fixed satisfactorily.

Item No-10 Supplying and fixing metal box of 180mm X 100mm X 60mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including providing and fixing 6 pin 5/6 & 15/16 A socket outlet and 15/16 A piano type switch, connections, painting etc. as required.

The item involves supplying and fixing metal box of 180mm X 100mm X 60mm deep (nominal size) on surface or in recess with suitable size of phenolic laminated sheet cover in front including providing and fixing 6 pin 5/6 & 15/16 A socket outlet and 15/16 A piano type switch, connections, painting etc. as required.

6 pin 5/6 & 15/16 A socket outlet shall be of polycarbonate electrical grade material, ISI marked of reputed brand conforming to IS:1293/2005.

15/16 A piano type switch shall be of polycarbonate electrical grade material, ISI marked of reputed brand conforming to IS:3854/1997.

GI Box should be made of 18 gauge, Mild steel of suitable size.

Frame plate of the switch board shall be made of Polycarbonate Electrical Grade of 2.5 mm thick and marked with manufacturers name / trade mark.

The height of switch board should be 1.2 meter from the ground level. Proper spacing must be provided between switch and socket. All the materials have to be got approved by the Engineer-in-charge before fixing. Agency has to Provide minimum 1 year of warranty for this item. If any fault comes proper replacement must be provided in minimum time. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made by number of 6 pin 5/6 & 15/16 A piano type socket outlet and 15/16 A piano type switch supplied and fixed satisfactorily.

Item No-11 Supplying and fixing two module stepped type electronic fan regulator on the existing modular plate switch box including connections but excluding modular plate etc. as required.

The item involves supplying and fixing two module stepped type electronic fan regulator on the existing switch box including connections but excluding modular plate etc. as required.

Stepped Type electronic fan regulator shall be of modular and capacitor type, suitable for fan up to 100W as per IS:11037:1984 with latest amendments. Size of 2 module, 230 V, ISI marked, polycarbonate electrical grade material, reputed brand on existing MS CRC sheet metal switch board.

All the materials have to be got approved by the Engineer-in-charge before fixing. Agency has to Provide minimum 1 year of warranty for this item. If any fault comes proper replacement must be provided in minimum time. Manufacturer test certificates need to be submitted. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for number of 2 M modular Step type electronic fan regulator supplied and fixed satisfactorily.

Item No-12 Supplying and fixing following piano type switch/ socket on the existing switch box/ cover including connections etc. as required.

12.01 5/6 amps switch

12.02 3 pin 5/6 A socket outlet

12.03 15/16 A switch

12.04 6 pin 15/16 A socket outlet

This item involves supplying and fixing following piano type switch/ socket on the existing switch box/ cover including connections etc. of the following ratings:-

- i) 5/6 amps switch shall be of polycarbonate electrical grade material, ISI marked of reputed brand conforming to IS:1293/2005.
- ii) 3 pin 5/6 amps socket outlet shall be of polycarbonate electrical grade material, ISI marked of reputed brand conforming to IS:3854/1997.
- iii) 15/16 A switch shall be of polycarbonate electrical grade material, ISI marked of reputed brand conforming to IS:1293/2005.
- iv) 6 pin 15/16 A socket outlet shall be of polycarbonate electrical grade material, ISI marked of reputed brand conforming to IS:3854/1997.

Proper spacing must be provided between switch and socket. All the materials have to be got approved by the Engineer-in-charge before fixing. Agency has to Provide minimum 1 year of warranty for this item. If any fault comes proper replacement must be provided in minimum time. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each switch and socket of 5/6 and 15/16 A rating supplied and fixed satisfactorily.

Item No-13 Earthing with G.I. earth pipe 4.5 metre long, 40 mm dia including

accessories, and providing masonry enclosure with cover plate having locking arrangement and watering pipe etc. with charcoal/ coke and salt as required.

The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each earthing rod supplied, and fixed satisfactorily into the earth for each LED Bollard light.

Item No-14 Providing and laying earth connection from earth electrode with 6 SWG dia G.I. Wire in 15 mm dia G.I. pipe from earth electrode including connection with G.I. thimble excavation and re-filling as required.

The item involves providing and laying earth connection from earth electrode with 6 SWG dia G.I. Wire in 15 mm dia G.I. pipe from earth electrode including connection with G.I. thimble excavation and re-filling as required. This G.I. wire will connect the earth G.I. plate to the earthing terminal of Main Switch and bus-bar. The earthing G.I. wire should be ISI marked. All the materials have to be got approved by the Engineer-in-charge before fixing. The item includes all materials, labour, tools & tackles etc. as required must be arranged by the agency. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made per running metre of 6 SWG dia Wire in 15 mm G.I. Pipe from earth electrode supplied and layed satisfactorily.

Item No-15 Supply, Installation, Testing and Commissioning of ceiling fan with Brush Less Direct Current (BLDC) Motor, class of insulation: B, 3 nos. metal(Aluminium alloy) blades, 30 cm long down rod, 2 nos. canopies, shackle kit, safety rope, copper winding, steel/Al body Power Factor not less than 0.9, Service Value (CM/M/W) minimum as below, 350 RPM (tolerance as per IS : 374-2019), THD (Total Harmonic Distortion) less than 10%, suitable for operation with regulator for speed control and all remaining accessories including safety pin, nut bolts, washers, temperature rise=75 0C (max.), insulation resistance more than 2 mega ohm, suitable for 230 V, 50 Hz, single phase AC supply, Ceiling Fan compliant to IS 374:2019 fan i/c external connections with 1.5 sq.mm FRLS/HFFR, PVC insulated copper conductor single core cable and earthing etc. as required 1200mm, service value \geq 6.0 CM/Min/Watt, air delivery 210 CM/Min (Minimum)

This items involves Supply, Installation, Testing and Commissioning of ceiling fan with Brush Less Direct Current (BLDC) Motor as per the specification mentioned in item.

The warranty card of the Manufacturer shall have to be submitted by the agency. Manufacturer test certificates need to be submitted. The item includes all materials, labour, tools & tackles etc. as required. The ceiling fan will be installed as per the location decided by the Engineer-In-charge. All the components should be of reputed brand (ISI marked) and brand and colour of the ceiling fan shall have to be got approved by the Engineer-In-Charge before supply. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each BLDC motor Ceiling fan supplied and installed satisfactorily.

Item No-16 Supplying of approved make exhaust fan heavy duty with mounting frame, blades AC 230-250, 225mm sweep RPM 900 / 1400 (9").

This item involves supplying of approved make exhaust fan heavy duty with mounting frame, blades AC 230-250, 225mm sweep RPM 900 / 1400 (9"). Exhaust fan have to be fixed after making hole in wall and making good damages and smooth cement finish etc. as practicable as possible and providing necessary length of PVC insulated wire and making connection for exhaust. Manufacturer test certificates need to be submitted. The item shall have to be got approved by the Engineer-In-Charge before fixing. Agency has to provide minimum 1 year of warranty for this item. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each exhaust fan supplied and fixed satisfactorily.

Item No-17 Supplying of different types of LED tubelight (20W) Make: Havells, LED ADORE 20 W B22 CDL 2 STAR LED LAMP.

This item involves supplying of different types of LED tubelight (20W) Make: Havells, LED ADORE 20 W B22 CDL 2 STAR LED LAMP. LED Tube light have to be fixed on wall 0.6 m below the ceiling with proper connection with ceiling rose. Manufacturer test certificates need to be submitted. Agency has to Provide minimum 1 year of warranty for this item. The item includes all materials, labour, tools & tackles etc. as required. All the components should be of reputed brand (ISI marked) and shall have to be got approved by the Engineer-In-Charge before supply and installation. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 20 watt LED Tube light supplied satisfactorily.

Item No-18 Supplying of different types of LED lamps (9W) Havells make, NU Bulb Plus 9 W 865 B22 3 Star.

This item involves supplying of different types of LED lamps (9W) Havells make, NU Bulb Plus 9 W 865 B22 3 Star.

LED bulb have to be fixed in the Lamp/batten holder provided in the point wiring. LED Make have to be got approved by the Engineer-in-charge before fixing. Agency must provide 1 year warranty for this item. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 9 watt LED Bulb supplied and fixed satisfactorily.

Item No-19 Supplying & fixing PVC insulated PVC sheathed copper conductor submersible flat cable ISI Marked in existing metal/ HDPE / PVC/ pipe/ in bore well/ in sump including fixing the cable to GI/HDPE pipe with suitable cable tags of following sizes etc. complete as required. 3 Core 4.0 Sq mm Flat Cable

The item involves supplying & fixing PVC insulated PVC sheathed copper conductor submersible flat cable ISI Marked in existing metal/ HDPE / PVC/ pipe/ in bore well/ in sump including fixing the cable to GI/HDPE pipe with suitable cable tags of following sizes etc. complete as required. 3 Core 4.0 Sq mm Flat Cable. This cable will be used for the connection of the motor installed at the barracks. There shall be

marking on the cable such as ISI mark, manufacturer name, month & year of manufacture, cable voltage grade FRLSH & type. The item includes all materials, labour, tools & tackles etc. as required. All the components should be of reputed brand (ISI marked) and shall have to be got approved by the Engineer-In-Charge before supply. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for running meter of supplied and drawing of 3 core, 4 sqmm Flat aluminium cable of reputed brand.

Item No-20 **Supply and fixing of smart bright street light complete with all accessories to be fixed /projected from the wall of the building or on pole incl. making holes/providing clamping arrangement & necy. GI reducer as required. S&F 40 mm GI pipe (ISI-Medium) quality 1.5 mts. average length having suitable bend S&F necy. length of 1.5 sqmm PVC insulated single core stranded annealed copper wire and making connections as required and mending good damages to wall incl. painting etc. Make: Havells, 30 W LED.**

The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 30 watt LED streetlight supplied and fixed satisfactorily.

Item No-21 **Supply and fixing of greenline V2 street light (115 Watt) complete with all accessories to be fixed /projected from the wall of the building or on pole incl. making holes/providing clamping arrangement & necy. GI reducer as required. S&F 40 mm GI pipe (ISI-Medium) quality 1.5 mts. average length having suitable bend S&F necy. length of 1.5 sqmm PVC insulated single core stranded annealed copper wire and making connections as required and mending good damages to wall incl. painting etc. Make : Philips, 115 watt.**

The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 115 watt LED streetlight supplied and fixed satisfactorily.

Item No-22 **Supplying swaged and welded steel tubular pole of following specifications as per IS 2317: 1980) 7m length, 73Kg, 410-SP-02.**

This item involves supplying swaged and welded steel tubular pole of following specifications as per IS 2317: 1980) 7m length, 73Kg, 410-SP-02. Manufacturer test certificates need to be submitted. The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 7m length, 73Kg, 410-SP-02 pole supplied and fixed satisfactorily.

Item No-23 **Erection of metallic pole of following length in cement concrete 1:3:6(1**

**cement: 3 coarse sand : 6 graded stone aggregate 40 mm nominal size)
foundation including excavation and refiling etc. as required. above 6.5
meter and upto 8.0 meter**

This item include Erection of metallic pole of following length in cement concrete 1:3:6(1 cement: 3 coarse sand : 6 graded stone aggregate 40 mm nominal size) foundation including excavation and refiling etc. as required. above 6.5 meter and upto 8.0 meter.

The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for Erection of each LED Street light metallic pole on cement concrete foundation (developed by agency with proper specification) satisfactorily.

Item No-24 Supplying & Fixing GI waterproof type looping cable box size 200x150x100 mm deep having 4 mm thick comprising of one 250 V 15 kit-kat fuse unit, one NL on porcelain insulator, one compression type brass cable gland for upto 2- core 16 sqmm PVC/A cable and having lined with rubber gasketted GI top cover with brass machine screws etc., earthing terminal with lug, on steel tubular pole near base, including S&F 40x6 mm thick, MS clamps with bolts, nuts etc. including painting with anticorrosive pain.

The item involves supplying and fixing GI water proof looping cable box as per specification mentioned above.

Each looping cable box will be installed for the Led street light pole. All the components should be of reputed brand (ISI marked) and shall have to be got approved by the Engineer-In-Charge before supply and fixing. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each GI water proof looping cable box supplied and fixed satisfactorily.

Item No-25 Supplying and laying of following size DWC HDPE pipe ISI marked along with all accessories like socket, bend, couplers etc. conforming to IS 14930, Part II complete with fitting and cutting, jointing etc.direct in ground (75 cm below ground level) including excavation and refilling the trench but excluding sand cushioning and protective covering etc., complete as required.63 mm dia (OD-63 mm & ID-51 mm nominal).

The item involves Supplying and laying of following size DWC HDPE pipe ISI marked along with all accessories like socket, bend, couplers etc. conforming to IS 14930, Part II complete with fitting and cutting, jointing etc. direct in ground (75 cm below ground level) including excavation and refilling the trench but excluding sand cushioning and protective covering etc., complete as required. 63 mm dia (OD-63 mm & ID-51 mm nominal). The 4 core X 10 sqmm Aluminium conductor armoured cable will be laid inside this HDPE pipe. The item includes all materials, labour, tools & tackles etc. as required arranged by agency. All the components should be of reputed brand (ISI marked) and shall have to be got approved by the Engineer-In-Charge before supply. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made per meter of 63 mm dia HDPE pipe supplied and layed in underground satisfactorily.

Item No-26 **Supplying and making end termination with brass compression gland and aluminium lugs for following size of PVC insulated and PVC sheathed / XLPE aluminium conductor cable of 1.1 KV grade as required.**

26.01 4 X 10 sq. mm (25mm)

26.02 4 X 25 sq. mm (28mm)

The item includes all materials, labour, tools & tackles etc. as required must be arranged by the agency. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each end termination of the cable of specified size at both side of cable satisfactorily.

Item No-27 **Supply and drawing of following XLPE Insulated Aluminium Conductor armored Cables of 1.1 KV Grade As per IS 7098 (PART 1) 1988 with up to date Amendments**

27. 01 4 core x 10 sqmm

27.02 4 core x 25 sqmm

The item involves Supply of above mentioned XLPE Aluminium conductor armoured cable LT 100 volts grade conforming IS : 7098 (Pat - I). The item includes all materials, labour, tools & tackles etc. as required supplied by the contractor. All the components should be of reputed brand (ISI marked) and shall have to be got approved by the Engineer-In-Charge before supply. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for running meter of above mentioned Aluminium conductor XLPE armoured cable supplied satisfactorily.

Item No-28 **Laying of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV grade of following size in the existing RCC/ HUME/ METAL pipe as required Upto 35 sq. mm.**

The item involves Laying Al conductor armoured cable in the existing HDPE pipe in underground trench. The item includes all materials, labour, tools & tackles etc. as required must be arranged by the agency. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made per metre laying of cable satisfactorily.

Item No-29 **Laying of one number PVC insulated and PVC sheathed / XLPE power cable of 1.1 KV grade of following size direct in ground including excavation, sand cushioning, protective covering and refilling the trench etc as required upto 35 sqmm.**

The item involves Laying Al conductor armoured cable direct in ground including excavation, sand cushioning, protective covering and refilling the trench etc as required upto 35 sqmm. The item includes all materials, labour, tools & tackles etc. as required must be arranged by the agency. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made per metre laying of cable satisfactorily.

Item No-30 **Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator) 6 way , Double door**

This item include supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections including earthing etc. as required. (But without MCB/RCCB/Isolator) 6 way , Double door.

The material of MCB DB Box shall be of Mild steel- properly pre-treated and stove enamelled / powder coated. 1.2 mm (MS Sheet) thickness, IP 43 Degree of Protection. MCB DB Box conforming to **IS code 13032:1991 latest**. Manufacturer test certificates need to be submitted. The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The height of SPN MCB DB Box should be 1.5 meter from the ground level. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 6 way MCB DB Box supplied and fixed satisfactorily.

Item No-31 **Supplying and fixing following rating, four pole, 415 V, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required. 40 A**

The item involves supplying and fixing following rating, four pole, 415 V, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required. 40 A. Complete set of test certificates need to be submitted. The Isolator should be of reputed brand (ISI marked) as given in estimate and shall have to be got approved by the Engineer-In-Charge before fixing. Agency has to Provide minimum 1 year of warranty for this item. Manufacturer test certificates need to be submitted. If any fault comes proper replacement must be provided at minimum time. The Isolator should be fixed in slot provided in the MCB DB Box with proper wiring connection. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each 40 A, four pole supplied and fixed satisfactorily.

Item No-32 **Earthing with 50 mm dia GI pipe 3.64 mm thick x 3.04 Mts. long and 1 x 4 SWG GI (Hot Dip) wire (4 Mts. long), 13 mm dia x 80 mm long GI bolts, double nuts, double washers incl. S & F 15 mm dia GI pipe protection (1 Mts. long) to be filled with bitumen partly under the ground level and partly above ground level driven to an average depth of 3.65 Mts. below the ground level as below: By TATA-Medium GI pipe.**

The item shall have to be got approved by the Engineer-In-Charge before fixing. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for each earthing rod supplied, and fixed satisfactorily into the earth for each LED street light pole.

Item No-33 Providing and laying earth connection from earth electrode with 6 SWG dia G.I. Wire in 15 mm dia G.I. pipe from earth electrode including connection with G.I. thimble excavation and re-filling as required.

The item involves Providing and laying earth connection from earth electrode with 6 SWG dia G.I. Wire in 15 mm dia G.I. pipe from earth electrode including connection with G.I. thimble excavation and re-filling as required. G.I. wire will connect the each street light pole. G.I. wire have to be got approved by the Engineer-in-charge before fixing. The item includes all materials, labour, tools & tackles etc. as required must be arranged by the agency. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made per running metre of 6 SWG G.I. wire supplied and fixed satisfactorily.

Item No-34 Painting with synthetic enamel paint of approved brand and manufacture of required colour to give an even shade one or more coats on old work.

The item involves supplying and fixing PVC casing-capping [Precision Make] on wall or ceiling, incl. necy. PVC fittings etc. and mending good damages to building works, 25X10 mm size. The Casing capping should be of reputed brand (ISI marked) as given in estimate and shall have to be got approved by the Engineer-In-Charge before fixing. PVC casing capping shall be complying to IS code **9537(part-3):183**. The casing capping shall be marked with Manufacturer's name or trade-mark, Nominal size of the conduits and ISI mark. The item includes all materials, labour, tools & tackles etc. as required. The work shall be done as per direction of the Engineer-In-Charge or his authorized representative.

The measurement and payment shall be made for running meter of 25 X 10 mm size PVC casing capping supplied and fixed satisfactorily.

Executive Engineer,
Electrical Division,
Farakka Barrage Project

LIST OF PREFERRED MAKES FOR ELECTRICAL WORKS

Approved makes of materials to be used in the work are as under. In case of non-availability of these makes, the Engineer-in-charge may allow use of alternative BIS makes of materials in the work.

No.	Material description	Approved Manufacturer / Brand Name
1.	Main Switch	Havells, Seimens, L&T
2.	MCB Distribution Box	Havells, L&T, ABB, Seimens, Crabtree, Schneider, Legrand, Polycab
3.	MCB	Havells, L&T, ABB, Seimens, Crabtree, Schneider, Legrand, Polycab
4.	FRLS PVC insulated copper conductor	Polycab, Havells, Finolex,
5.	5/6 amps, 15/16 amp switch and socket	Anchor, Havells Reo, Legrand
6.	12" Exhaust fan	Havells, Crompton, Orient, Polycab
7.	115 & 30 watt LED street light	Philiphs, Havells, Crompton, Orient, Polycab
8.	20 watt LED Tubelight	Philiphs, Havells, Crompton, Orient, Polycab
9.	9 watt LED Bulb	Philiphs, Havells, Crompton, Orient, Polycab
10.	20 watt LED Recess Light	Philiphs, Havells, Crompton, Orient, Polycab
11.	Aluminium conductor cables	Havells, Polycab, Gloster, KEI
12.	BLDC motor ceiling fan, 5 star rating	Havells, Crompton, Orient, Polycab, Atomberg
13.	Ceiling rose, Bulb Holder	Anchor
14.	PVC casing capping, PVC Conduit	Presto plast, Anchor, AKG
15.	7 mtr steel tubular pole	Utkarsh, Tata, Addmast etc or as per approval of EIC.

Note:-In respect of other materials, any ISI marked material can be used on the work. In case of non-availability decision of Engineer-in-Charge shall be binding and final.

Executive Engineer
Electrical Division,
Farakka Barrage Project

SCHEDULE – D-2

OTHER TERMS AND CONDITIONS

1. Measurement: -

Engineer-in-Charge shall, except as otherwise provided, ascertain and determine by measurement the value of work done in accordance with the contract.

All measurements of all items having financial value shall be entered by the contractor and compiled in the shape of the **Computerized Measurement Book** having pages of A-4 size as per the format of the department so that a complete record is obtained of all the items of works performed under the contract.

All such measurements and levels recorded by the contractor or his authorized representative from time to time, during the progress of the work, shall be got checked by the contractor from the Engineer-in-Charge or his authorized representative as per interval or program fixed in consultation with Engineer-in-Charge or his authorized representative. After the necessary corrections are made by the Engineer-in-Charge, the measurement sheets shall be returned to the contractor for incorporating the corrections and for resubmission to the Engineer-in-Charge for the dated signatures by the Engineer-in-Charge and the contractor or their representatives in token of their acceptance.

Whenever bill is due for payment, the contractor would initially submit draft computerized measurement sheets and these measurements would be got checked/test checked from the Engineer-in-Charge and/or his authorized representative. The contractor will, thereafter, incorporate such changes as may be done during these checks/test checks in his draft computerized measurements, and submit to the department a computerized measurement book, duly bound, and with its pages machine numbered. The Engineer-in-Charge and/or his authorized representative would thereafter check this MB, and record the necessary certificates for their checks/test checks

The final, fair, computerized measurement book given by the contractor, duly bound, with its pages machine numbered, should be 100% correct, and no cutting or over-writing in the measurements would thereafter be allowed. If at all any error is noticed, the contractor shall have to submit a fresh computerized MB with its pages duly machine numbered and bound, after getting the earlier MB cancelled by the department. Thereafter, the MB shall be taken in the Divisional Office records, and allotted a number as per the Register of Computerized MBs. This should be done before the corresponding bill is submitted to the Division Office for payment. The contractor shall submit two spare copies of such computerized

MBs for the purpose of reference and record by the various officers of the department.

The contractor shall also submit to the department separately his computerized Abstract of Cost and the bill based on these measurements, duly bound, and its pages machine numbered along with two spare copies of the "bill. Thereafter, this bill will be processed by the Division Office and allotted a number as per the computerized record in the same way as done for the measurement book meant for measurements.

The contractor shall, without extra charge, provide all assistance with every appliance, labour and other things necessary for checking of measurements /levels by the Engineer in-Charge or his representative.

Except where any general or detailed description of the work expressly shows to the contrary, measurements shall be taken in accordance with the procedure set forth in the specifications notwithstanding any provision in the relevant Standard Method of measurement or any general or local custom. In the case of items which are not covered by specifications, measurements shall be taken in accordance with the relevant standard method of measurement issued by the Bureau of Indian Standards and if for any item no such standard is available then a mutually agreed method shall be followed.

The contractor shall give not less than seven days' notice to the Engineer-in-Charge or his authorized representative in charge of the work before covering up or otherwise placing beyond the reach of checking and/or test checking the measurement of any work in order that the same may be checked and/or test checked and correct dimensions thereof be taken before the same is covered up or placed beyond the reach of checking and/or test checking measurement and shall not cover up and place beyond reach of measurement any work

without consent in writing of the Engineer-in-Charge or his authorized representative in charge of the work who shall within the aforesaid period of seven days inspect the work, and if any work shall be covered up or placed beyond the reach of checking and/or test checking measurements without such notice having been given or the Engineer-in-Charge's consent being obtained in writing the same shall be uncovered at the Contractor's expense, or in default thereof no payment or allowance shall be made for such work or the materials with which the same was executed.

Engineer-in-Charge or his authorized representative may cause either themselves or through another officer of the department to check the measurements recorded by contractor and all provisions stipulated herein above shall be applicable to such checking of measurements or levels.

It is also a term of this contract that checking and/or test checking the measurements of any item of work in the measurement book and/or its payment in the interim, on account of final bill shall not be considered as conclusive evidence as to the sufficiency of any work or material to which it relates nor shall it relieve the contractor from liabilities from any over measurement or defects noticed till completion of the defect's liability period.

2. Register: -

The contractor shall maintain all the register related to work like, Inspection register, Site instruction register, Labour register, Hindrance register (if applicable), daily progress register, Dismantling of Materials Register, others materials consumption Register (if applicable), in prescribed format by the Engineer in charge. Photo copy of all registers should be submitted with Running /Final Bill.

3. Time schedule: -

The work shall be completed within 4 months after placement of Work Order.

Executive Engineer
Electrical Division,
Farakka Barrage Project

SCHEDULE – D-3

ADDITIONAL TERMS & CONDITIONS:

- 1) Location of works, land and mode of transportation
 - (i) Location of works

At Mahapagla and Bansloir Regulators, of the FBP in the District of Murshidabad, West Bengal
 - (ii) Land

As the project land is available, as such no land is required for this work.
 - (iii) Mode of transportation for carriage of materials

Trucks, cart etc., if required for carriage and handling of materials shall be arranged by the contractor at his own cost and initiative. In case of colony roads being utilized by the contractor for transporting men and materials to site, any damage caused to these roads shall be rectified by the contractor at his own cost and initiative and no claim on account of this shall be entertained.

If situation demands, the printed challans in a book form with numbering shall be arranged by the contractor for transport of materials necessary for the work from the stacking yard to actual place of utilization as per direction of the EIC.
- 2) There is likelihood that some other works may also be under execution simultaneously by other agencies in the adjoining area. The contractor shall execute the works without causing any hindrance / disruption to such works.
- 3) The contractor shall intimate the EIC about the number of labourers engaged daily for execution of the work. A register shall be maintained by him for this purpose. **The contractor has to submit Fortnightly Labour Return (FLR) as per Clause 19D of GCC for CPWD works.**
- 4) The contractor is solely responsible for watch and ward of the materials for the work till completion and handing over of the site to the Department. For any loss, theft or damage of materials under custody during execution of the work, the contractor is liable to make up for such loss as deemed fit by the Department.
- 5) If the situation demands, the EIC has the right to review the situation as regards to possibility of execution of the works. In case it is not possible to execute the works, necessary instructions shall be issued by the Department to temporarily / permanently close the works, which shall be binding on the contractor and no claim, whatsoever, for sudden suspension / closure of works shall be admissible.
- 6) All the materials brought to the site must be subject to approval of the Engineer-In-Charge or his authorized representative. Rejected materials must be removed by the contractor at his own cost from the site within 24 hours of the issue of order to that effect. In case of non-compliance with such orders, the Engineer-In-Charge shall have the authority to cause such removal at the cost and expense of the contractor and the contractor shall not be entitled to any loss or damage on this account.
- 7) The Department shall deduct GST @ 2% as per Govt. rule, Income Tax @ 2% and Labour Welfare Cess @ 1% or any other prevailing tax at the time of releasing payment of interim bills / final bill in accordance with Central Government / Govt. of West Bengal Finance Acts where applicable.
- 8) The land which will be required for contractor's camp / labour hutments etc. shall be allotted to the contractor on rental basis as per departmental approved rates provided it can be spared for this purpose. If the land is not available with the Department, camp / labour hutments etc. may

be established by the contractor at his own initiative and cost and no claim on this account shall be entertained by the Department.

9) Accident

- (i) It shall be the responsibility of the contractor to protect the workmen, engaged by him in the works, against accidents. He shall indemnify the Department against any claim for damages or for any injury to persons or property resulting from and in the course of works and also under the provision of the Workmen's Compensation Act, 1923.
- (ii) On the occurrence of an accident arising out of the work which results in death or any injury which is so serious as to likely to result in death, the contractor shall within 24 (twenty four) hours of such an accident, report in writing, to the Engineer- in-charge and District Labour Officer stating clearly the facts and circumstances of the accident and the action taken. All other accidents on the works involving injuries to persons or damages to properties other than that of contractor shall be promptly reported to the Engineer- in-charge and District Labour Officer stating clearly the facts and circumstances of the accident and the action taken.
- (iii) In all cases, the contractor shall indemnify the Department against the contractor's failure to report in the matter aforesaid. This includes penalties or fines, if any, payable by the Govt. as a consequence of failure to give notice under the Workmen's Compensation Act, 1923 or failure to conform to the provisions of the said Act in regard to such accidents. In the event of an accident in respect of which compensation may become payable by the contractor under the Workmen's Compensation Act-VIII, 1923 including all modifications thereof, the Engineer- in-charge may retain payment due to the contractor, such a sum of money which in the opinion of the Engineer- in-charge shall be sufficient to meet such liabilities. On receipt of award from the Labour Commissioner, in respect of quantum of compensation, the difference in amount may be adjusted.

10) Losses/ damages/ theft of Govt. materials

During execution of the work, the contractor shall take due care so that no Govt. materials are damaged, lost or pilfered in any shape/ extent. If such incidents do occur, it shall be immediately brought to the notice of the Engineer- in-charge. The contractor shall be held responsible for the same and he shall replace / refit the materials in position at his own cost and initiative as per the orders and approval of the Engineer- in-charge.

Executive Engineer
Electrical Division
Farakka Barrage Project

SCHEDULE – D-4

PAYMENT

1. Running payment will be allowed subject to availability of funds.
2. Income Tax, GST, Labour Welfare, and any other tax (es) and duties if any enforce that will be deducted from the bills.
3. 5% Security Deposit will be deducted from the bill which will be refunded in due course of time as per rule.
4. No claim of escalation will be entertained.
5. To enable ECS payment of the bills, the requisite format shall be submitted duly signed by the appropriate signatories.

Executive Engineer
Electrical Division,
Farakka Barrage Project

INTEGRITY PACT

.....
.....
.....
.....

Sub: NIT No. GM/FBP-01 of 2026-27 for the work of "***Renovation/ replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP'***".

Dear Sir,

It is hereby declared that Farakka Barrage Project (FBP) is committed to follow the principle of transparency equity and competitiveness in public procurement.

The subject Notice Inviting Tender (NIT) is an invitation to offer made on the condition that the bidder will sign the Integrity Agreement, which is an integral part of tender / bid documents, failing which the tenderer / bidder will stand disqualified from the tendering process and the bid of the bidder would be summarily rejected.

This declaration shall form part and parcel of the Integrity Agreement and signing of the same shall be deemed as acceptance and signing of the Integrity Agreement on behalf of the Farakka Barrage Project (FBP).

Yours faithfully

Executive Engineer
Electrical Division
Farakka Barrage Project

INTEGRITY PACT

To,
The Executive Engineer,
Electrical Division,
Farakka Barrage Project,
Farakka, West Bengal

Sub: Submission of Tender for the Work "***Renovation/ replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP***".

Dear Sir,

I/We acknowledge that FBP is committed to follow the principles thereof as enumerated in the Integrity Agreement enclosed with the tender/bid document.

I/We agree that the Notice Inviting Tender (NIT) is an invitation to offer made on the condition that I/We will sign the enclosed integrity Agreement, which is an integral part of tender documents, failing which I/We will stand disqualified from the tendering process. I/We acknowledge that THE MAKING OF THE BID SHALL BE REGARDED AS AN UNCONDITIONAL AND ABSOLUTE ACCEPTANCE of this condition of the NIT.

I/We confirm acceptance and compliance with the Integrity Agreement in letter and spirit and further agree that execution of the said Integrity Agreement shall be separate and distinct from the main contract, which will come into existence when tender/bid is finally accepted by. I/We acknowledge and accept the duration of the Integrity Agreement, which shall be in the line with Article 1 of the enclosed Integrity Agreement.

I/We acknowledge that in the event of my/our failure to sign and accept the Integrity Agreement, while submitting the tender/bid, FBP shall have unqualified, absolute and unfettered right to disqualify the tenderer/bidder and reject the tender/bid in accordance with terms and conditions of the tender/bid.

Yours faithfully

(Duly authorized signatory of the Bidder)

To,

The Executive Engineer
Electrical Division,
Farakka Barrage Project

To be signed by the bidder and same signatory competent / authorized to sign the relevant contract on behalf of Farakka Barrage Project

INTEGRITY AGREEMENT

This Integrity Agreement is made at _____ on this _____ day of 2026

BETWEEN

President of India represented through the Executive Engineer, Electrical Division, Farakka Barrage Project, Farakka, West Bengal (Hereinafter referred as the '**Principal/Owner**', which expression shall unless repugnant to the meaning or context hereof include its successors and permitted assigns)

AND

(Name and Address of the Individual/firm/Company)

Through _____ (details of duly authorized signatory) (Hereinafter referred to as the "**Bidder/Contractor**" and which expression shall unless repugnant to the meaning or context hereof include its successors and permitted assigns)

Preamble

WHEREAS the Principal / Owner has floated the Tender (NIT No.**GM/FBP- 01 of 2026-27** (hereinafter referred to as "**Tender/Bid**") and intends to award, under laid down organizational procedure contract for "**Renovation/ replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP**".

Here in after referred to as the "**Contract**"

AND WHEREAS the Principal/Owner values full compliance with all relevant laws of the land, rules, regulations, economic use of resources and of fairness/transparency in its relation with its Bidder(s) and Contractor(s).

AND WHEREAS to meet the purpose aforesaid both the parties have agreed to enter into this Integrity Agreement (hereinafter referred to as "**Integrity Pact**" or "**Pact**"), the terms and conditions of which shall also be read as integral part and parcel of the Tender/Bid documents and Contract between the parties.

NOW, THEREFORE, in consideration of mutual covenants contained in this Pact, the parties hereby agree as follows and this Pact witnesses as under:

Article 1: Commitment of the Principal/Owner

- 1) The Principal/Owner commits itself to take all measures necessary to prevent corruption and to observe the following principles:

- (a) No employee of the Principal/Owner, personally or through any of his/her family members, will in connection with the Tender, or the execution of the Contract, demand, take a promise for or accept, for self or third person, any material or immaterial benefit which the person is not legally entitled to.
- (b) The Principal/Owner will, during the Tender process, treat all Bidder(s) with equity and reason. The Principal/Owner will, in particular, before and during the Tender process, provide to all Bidder(s) the same information and will not provide to any Bidder(s) confidential / additional information through which the Bidder(s) could obtain an advantage in relation to the Tender process or the Contract execution.
- (c) The Principal/Owner shall endeavour to exclude from the Tender process any person, whose conduct in the past has been of biased nature.
- 2) If the Principal/Owner obtains information on the conduct of any of its employees which is a criminal offence under the Indian Penal code (IPC)/Prevention of Corruption Act, 1988 (PC Act) or is in violation of the principles herein mentioned or if there be a substantive suspicion in this regard, the Principal/Owner will inform the Chief Vigilance Officer and in addition can also initiate disciplinary actions as per its internal laid down policies and procedures

Article 2: Commitment of the Bidder(s)/Contractor(s)

- 1) It is required that each Bidder/Contractor (including their respective officers, employees and agents) adhere to the highest ethical standards, and report to the Government / Department all suspected acts of **fraud or corruption or Coercion or Collusion** of which it has knowledge or becomes aware, during the tendering process and throughout the negotiation or award of a contract.
- 2) The Bidder(s)/Contractor(s) commit himself to take all measures necessary to prevent corruption. He commits himself to observe the following principles during his participation in the Tender process and during the Contract execution.
 - a) The Bidder(s)/Contractor(s) will not, directly or through any other person or firm, offer, promise or give to any of the Principal/Owner's employees involved in the Tender process or execution of the Contract or to any third person any material or other benefit which he/she is not legally entitled to, in order to obtain in exchange any advantage of any kind whatsoever during the Tender process or during the execution of the Contract/
 - b) The Bidder(s)/Contractor(s) will not enter with other Bidder(s) into any undisclosed agreement or understanding, whether formal or informal. This applies in particular to prices, specifications, certifications, subsidiary contracts, submission or non-submission of bids or any other actions to restrict competitiveness or to cartelize in the bidding process.
 - c) The Bidder(s)/Contractor(s) will not commit any offence under the relevant IPC/PC Act. Further the Bidder(s)/Contract(s) will not use improperly, (for the purpose of competition or personal gain), or pass on to others, any information or documents provided by the Principal/Owner as part of the business relationship, regarding plans, technical proposals and business details, including information contained or transmitted electronically.
 - d) The Bidder(s)/Contractor(s) of foreign origin shall disclose the names and addresses of agents/representatives in India, if any. Similarly Bidder(s)/ Contractor(s) of Indian

Nationality shall disclose names and addresses of foreign agents/representatives, if any. Either the Indian agent on behalf of the foreign principal or the foreign principal directly could bid in a tender but not both. Further, in cases where an agent participate in a tender on behalf of one manufacturer, he shall not be allowed to quote on behalf of another manufacturer along with the first manufacturer in a subsequent/parallel tender for the same item.

- e) The Bidder(s)/Contractor(s) will, when presenting his bid, disclose (with each tender as per pro forma enclosed) any and all payments he has made, is committed to or intends to make to agents, brokers or any other intermediaries in connection with the award of the Contract.
- 3) The Bidder(s)/Contractor(s) will not instigate third persons to commit offences outlined above or be an accessory to such offences.
- 4) The Bidder(s)/Contractor(s) will not, directly or through any other person or firm indulge in fraudulent practice **means a wilful misrepresentation or omission of facts or submission of fake/forged documents in order to induce public official to act in reliance thereof, with the purpose of obtaining unjust advantage by or causing damage to justified interest of others and/or to influence the procurement process to the detriment of the Government interests.**
- 5) The Bidder(s)/Contractor(s) will not, directly or through any other person or firm use Coercive Practices (means the act of obtaining something, compelling an action or influencing a decision through intimidation, threat or the use of force directly or indirectly, where potential or actual injury may befall upon a person, his/ her reputation or property to influence their participation in the tendering process).

Article 3: Consequences of Breach

Without prejudice to any rights that may be available to the Principal/Owner under law or the Contract or its established policies and laid down procedures, the Principal/Owner shall have the following rights in case of breach of this Integrity Pact by the Bidder(s)/Contractor(s) and the Bidder/ Contractor accepts and undertakes to respect and uphold the Principal/Owner's absolute right:

- 1) If the Bidder(s)/Contractor(s), either before award or during execution of Contract has committed a transgression through a violation of Article 2 above or in any other form, such as to put his reliability or credibility in question, the Principal/Owner after giving 14 days' notice to the contractor shall have powers to disqualify the Bidder(s)/Contractor(s) from the Tender process or terminate/determine the Contract, if already executed or exclude the Bidder/Contractor from future contract award processes. The imposition and duration of the exclusion will be determined by the severity of transgression and determined by the Principal/Owner. Such exclusion may be forever or for a limited period as decided by the Principal/Owner.
- 2) **Forfeiture of bid security/Performance Security:**

If the Principal/Owner has disqualified the Bidder(s) from the Tender process prior to the award of the Contract or terminated/ determined the Contract or has accrued the right to terminate/determine the Contract according to Article 3(1), the Principal/Owner apart from exercising any legal rights that may have accrued to the Principal/Owner, may in its

considered opinion forfeit the entire amount of bid security, Performance security of the Bidder/ Contractor.

- 3) **Criminal Liability:** If the Principal/Owner obtains knowledge of conduct of a Bidder or Contractor, or of an employee or a representative or an associate of a Bidder or Contractor which constitutes corruption within the meaning of Indian Penal code (IPC)/Prevention of Corruption Act, or if the Principal/Owner has substantive suspicion in this regard, the Principal/Owner will inform the same to law enforcing agencies for further investigation.

Article 4: Previous Transgression

- 1) The Bidder declares that no previous transgressions occurred in the last 5 years with any other Company in any country confirming to the anticorruption approach or with Central Government or State Government or any other Central/State Public Sector Enterprises in India that could justify his exclusion from the Tender process.
- 2) If the Bidder makes incorrect statement on this subject, he can be disqualified from the Tender process or action can be taken for banning of business dealings/ holiday listing of the Bidder/Contractor as deemed fit by the Principal/ Owner.
- 3) If the Bidder/Contractor can prove that he has resorted / recouped the damage caused by him and has installed a suitable corruption prevention system, the Principal/Owner may, at its own discretion, revoke the exclusion prematurely.

Article 5: Equal Treatment of all Bidders/Contractors/Subcontractors

- 1) The Bidder(s)/Contractor(s) undertake(s) to demand from all subcontractors a commitment in conformity with this Integrity Pact. The Bidder/Contractor shall be responsible for any violation(s) of the principles laid down in this agreement/Pact by any of its Sub contractors/sub-vendors.
- 2) The Principal/Owner will enter into Pacts on identical terms as this one with all Bidders and Contractors.
- 3) The Principal/Owner will disqualify Bidders, who do not submit, the duly signed Pact between the Principal/Owner and the bidder, along with the Tender or violate its provisions at any stage of the Tender process, from the Tender process.

Article 6- Duration of the Pact

This Pact begins when both the parties have legally signed it. It expires for the Contractor/Vendor 12 months after the completion of work under the contract or till the continuation of defect liability period, whichever is more and for all other bidders, till the Contract has been awarded. If any claim is made/lodged during the time, the same shall be binding and continue to be valid despite the lapse of this Pacts as specified above, unless it is discharged/determined by the Competent Authority, FBP.

Article 7- Other Provisions

- 1) This Pact is subject to Indian Law, place of performance and jurisdiction is the **Head quarters of the Division** of the Principal/Owner, who has floated the Tender.
- 2) Changes and supplements need to be made in writing. Side agreements have not been made.
- 3) If the Contractor is a partnership or a consortium, this Pact must be signed by all the partners or by one or more partner holding power of attorney signed by all partners and consortium members. In case of a Company, the Pact must be signed by a representative duly authorized by board resolution.

- 4) Should one or several provisions of this Pact turn out to be invalid; the remainder of this Pact remains valid. In this case, the parties will strive to come to an agreement to their original intentions.
- 5) It is agreed term and condition that any dispute or difference arising between the parties with regard to the terms of this Integrity Agreement / Pact, any action taken by the Owner/Principal in accordance with this **Integrity Agreement/ Pact or interpretation thereof shall not be subject to arbitration.**

Article 8- LEGAL AND PRIOR RIGHTS

All rights and remedies of the parties hereto shall be in addition to all the other legal rights and remedies belonging to such parties under the Contract and/or law and the same shall be deemed to be cumulative and not alternative to such legal rights and remedies aforesaid. For the sake of brevity, both the Parties agree that this Integrity Pact will have precedence over the Tender/Contact documents with regard any of the provisions covered under this Integrity Pact.

IN WITNESS WHEREOF the parties have signed and executed this Integrity Pact at the place and date first above mentioned in the presence of following witnesses:

.....
(For and on behalf of Principal/Owner)

.....
(For and on behalf of Bidder/Contractor)

(Ref. Para 7.4 of Chapter-7)

MODEL BANK GUARANTEE FORMAT FOR PERFORMANCE SECURITY

To
The President of India

WHEREAS(Name and address of the supplier) (hereinafter called "the supplier") has undertaken, in pursuance of Contract No. Datedto supply (description of goods and services) (herein after called "the contract").

AND WHEREAS it has been stipulated by you in the said contract that the supplier shall furnish you with a bank guarantee by a scheduled commercial recognized by you for the sum specified therein as security for compliance with its obligation in accordance with the contract;

AND WHEREAS we have agreed to give the supplier such a bank guarantee;

Now THEREFORE we hereby affirm that we are guarantors and responsible to you, on behalf of the supplier, up to a total of

(amount of the guarantee in words and figures), and we undertake to pay you, upon your first written demand declaring the supplier to be in default under the contract and without cavil or argument, any sum or sums within the limits of (amount of guarantee) as aforesaid, without your needing to prove or show grounds or reasons for your demand or the sum specified therein.

We hereby waive the necessity of your demanding the said debt from the supplier before presenting us with the demand.

We further agree that no change or addition to or other modification of the terms of the contract to be performed there under or of any of the contract documents which may be made between you and the supplier shall in any way release us from any liability under this guarantee and we hereby waive notice of any such change, addition or modification.

This guarantee shall be valid until the day of, 20.....

(Signature of the authorized Officer of the Bank)

.....
Name and designation of the officer
.....
.....

Seal, name & address of the Bank and address of the Branch

FINANCIAL INFORMATION

- I. Financial Analysis – Details to be furnished duly supported by figures in balance sheet/ profit & loss account for the last five financial years duly certified by the Chartered Accountant, as submitted by the applicant to the Income Tax Department (Copies to be attached).

Financial years			
-----------------	--	--	--

- (i) Gross Annual Turn Over on construction works.
- (ii) Profit/Loss.

- II. Financial arrangements for carrying out the proposed work.

Signature of Chartered Accountant with Seal & UDIN number

Signature of Bidder(s)

ANNEXURE-III**DETAILS OF ELIGIBLE SIMILAR NATURE OF WORKS COMPLETED DURING THE LAST SEVEN YEARS ENDING THE LAST DAY OF THE MONTH PREVIOUS TO THE ONE IN WHICH APPLICATIONS ARE INVITED**

Sl No.	Name of work/project and location	Owner or sponsoring organization	Cost of work in crores of rupees	Date of commencement as per contract	Stipulated date of completion
1	2	3	4	5	6

Actual date of completion	Litigation/ arbitration cases pending/ in progress with details*	Name and address/ telephone number of officer to whom reference may be made	Whether the work was done on back to back basis Yes/ No
7	8	9	10

* Indicate gross amount claimed and amount awarded by the Arbitrator.

Signature of Bidder(s)

NET WORTH CERTIFICATE

(On the Letter head of Registered Chartered Accountant)

This is to certify that the Net worth of M/s. /Mr./Ms. as on is Rupees only as per the statement of computation of even date annexed hereto. It is further certified that the computation of Net worth, based on my/our scrutiny of the books of accounts, records and documents, is true and correct to the best of my/our knowledge and as per information provided to my/our satisfaction.

Place:

For (Name of Accounting Firm)

Date:

Name of partner Chartered Accountant Membership Number & UDIN number

(Rubber Stamp)

Computation of Net worth

(Annexure forming part of the Net Worth Certificate of Dated -----)

The net worth has been computed as per the format given below for the Financial Year ending _____:

(Rs in Crores)

Paid up Capital (A)	
Add: Equity Share Premium	
Add: Reserve & Surplus (excluding revaluation reserves) (C)	
Less: Statutory Reserves (D)	
Less: Revaluation Reserves (E)	
Less: Accumulated losers if any – (F)	
Less: Miscellaneous Expenditure to the extent not written off – (H)	
Total Net worth (A+B+C)-(D+E+F+G+H)	

For (Name of Accounting Firm)

Place:

Name of Partner Chartered Accountant Membership Number and UDIN

Date:

(Rubber Stamp)

(BANK SOLVENCY CERTIFICATE FORMAT)
(On bank's letter head)

(To be issued by Nationalized banks/ scheduled banks as mentioned below)

SOLVENCY CERTIFICATE

Ref. No. _____

Date: _____

This is to certify that to the best of our knowledge and information, M/s _____
(bidder's name with complete address), a customer of our bank, is respectable, and is solvent
to the extent of Rs. _____ (Amount in words _____).

M/s _____ have been our customer since _____ to till date and has been granted
the following limits, at present, against various facilities granted by the bank.

This certificate is issued without any risk/ liability or responsibilities whatsoever on the part of
the Bank or any of its officers.

This certificate is issued at the specific request of the customer.

Yours faithfully

(Bank official's signature & stamp)

Self certificate under Rule 144 (xi) of the General Financial Rules (GFRs),
2017
(On Bidders Letter head)

"We have read the clause regarding restrictions on procurement from a bidder of a country which shares a land border with India; we certify that (Name of firm / bidder) is not from such a country or, if from such a country, has been registered with the Competent Authority. We hereby certify that (Name of Firm / Bidder) fulfils all requirements in this regard and is eligible to be considered".
(Where applicable, evidence of valid registration by the Competent Authority shall be attached).

Name: (insert complete name of person signing the certificate)

Duly authorized to sign the bid for an on behalf of (insert complete name of Bidder)

Dated on _____ day of _____ (insert date of signing)

Corporate Seal (where appropriate)

FORMAT OF BID SECURITY DECLARATION FROM BIDDERS IN LIEU OF EMD
(On Bidders Letter head)

Bid Security Declaration Form

Date: _____ Tender No. _____

To (insert complete name and address of the purchaser)

I/ We, the undersigned, declare that:

I/ We understand that, according to your conditions, bids must be supported by a Bid Securing Declaration.

I/We accept that I/We may be disqualified from bidding for any contract with you for a period of one year from the date of notification if I am /We are in a breach of any obligation under the bid conditions, because I/We

- a) have withdrawn/modified/amended, impairs or derogates from the tender, my/our Bid during the period of bid validity specified in the form of Bid; or
- b) having been notified of the acceptance of our Bid by the purchaser during the period of bid validity (i) fail or reuse to execute the contract, if required, or (ii) fail or refuse to furnish the Performance Security, in accordance with the Instructions to Bidders.

I/We understand this Bid Securing Declaration shall cease to be valid if I am/we are not the successful Bidder, upon the earlier of (i) the receipt of your notification of the name of the successful Bidder; or (ii) thirty days after the expiration of the validity of my/our Bid.

Signed: (insert signature of person whose name and capacity are shown)

in the capacity of (insert legal capacity of person signing the Bid Securing Declaration)

Name: (insert complete name of person signing the Bid Securing Declaration)

Duly authorized to sign the bid for an on behalf of (insert complete name of Bidder)

Dated on _____ day of _____ (insert date of signing)

Corporate Seal (where appropriate)

SITE / PLANT VISIT REPORT

Tender No. / GeM Bid No.

Tender Title: **Renovation/ replacement of electrical wiring of the CISF barracks including illumination of approach road with LED street light poles at Mahapagla and Bansloi Regulators of FBP.**

M/s hereby declares that I / we have visited Site(s) / premises located at

All our doubts and queries with respect to scope of work, terms & conditions of the tender document were replied / clarified satisfactory.

I / We have fully understood the scope / nature of the work and the conditions.

Representative of Bidder:

Representative of FBP:

Name:

Name:

Signature:

Signature:

Date:

Date:

Place:

Place:

Note: The representative of the bidder must submit the authorization letter of the agency in their letter pad for attending the site visit. This declaration is to be submitted along with the documents required to be submitted in hard copy as mentioned in the tender document.