

**ANNEXURE-I**

**Name of work :-** DG - WALUJ INDUSTRIAL AREA .. Centralized Water Supply Scheme at Waluj...

Replacement of old M.S. pipeline from Shekta Phata to WTP Waluj with 1800 mm dia MS raw water rising main and allied works...

**Approval to replies to queries received online, by e-mail and queries raised during pre-bid meeting and additional clarification by MIDC**

**Ref :-** E-Tender Notice No. 02/A/01 / 2026-2027

The replies by MIDC about various points by prospective bidders through queries submitted on website, e-mails and queries during pre-bid meeting and additional clarification by MIDC are as follows :

| Sr No  | Page No.       | Ref. Clause No.        | Tender Clause  | Query raised  | MIDC's Reply | Remarks |
|--|----------------|------------------------|--|---|--------------|---------|
| <b>A) Replies to queries received on E-mail:</b>                   |                |                        |  |   |              |         |
| <b>M/S Shreehari Associates Pvt.Ltd. Chhatrapati Sambhajinagar</b> |                |                        |  |   |              |         |
| 1  | Page No. 3/244 | Detailed Tender Notice | A) Single work of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.8768.30 Lakhs or Single work of providing, laying and jointing M.S. water supply pipeline having length not less than 8.60 Km and having diameter not less than 900 mm.<br><b>OR</b><br>B) Total cost of two works of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.12275.60 Lakhs or two works of providing, laying | Kindly confirm whether experience in DI / HDPE pipe laying will be considered towards the eligibility criteria. | As per NIT   |         |

| Sr No | Page No.     | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply   | Remarks |
|-------|--------------|------------------------|---|--|--|---------|
|       |              |                        | <p>and jointing M.S. water supply pipeline having length not less than 12.04 Km and having diameter not less than 900 mm.</p> <p><b>OR</b></p> <p>C) Total cost of three works of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.14029.25 Lakhs or three works of providing, laying and jointing M.S. water supply pipeline having length not less than 13.76 Km and having diameter not less than 900mm.</p> |  |  |         |
| 2     | ---          | ---                    | ---   | Please specify the minimum width of land acquired or proposed by MIDC for working space along the entire chainage  | Proposed pipe line is to be laid adjacent to the existing pipeline on road side within the road land width.                    |         |
| 3     | Page No. 233 | Schedule B Item No. 47 | <p>Providing flush grooved pointing with cement mortar 1:3 for stone masonry work including scaffolding and curing etc. complete.</p> <p>Unit – Sqare Kilometer</p>   | In BOQ Sr. No. 6.1 "Providing flush grooved pointing with cement mortar 1:3 for stone masonry work including scaffolding and curing etc. complete," the unit is mentioned as 550 Sq.m. Kindly confirm or correct the same. | The Unit of item no. 47 of "Schedule B" of the subject work (pointing work) shall be read as Sq.m instead of Square kilometer. |         |

| Sr No | Page No.     | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply  | Remarks |
|-------|--------------|------------------------|---|--|---|---------|
| 4     | ---          | ---                    | ---   | We request you to provide detailed drawings, as the same are currently not available on the web portal.  | The Alignment plan of the proposed pipeline is attached as per Annexure-II.   |         |
| 5     | ---          | ---                    | ---   | Kindly clarify whether the proposed new pipeline is to be laid alongside the existing pipeline on the roadside or on the farmer's land side. We also request a tentative layout and drawings for the same.   | It is proposed to lay new pipeline adjacent to existing pipeline on the road side within the road land width.   |         |
| 6     | Page No. 171 | Price Variation Clause | P= Cost of work done during the quarter under consideration minus the cost of cement, HYSD & mild steel, bitumen, CI & DI pipes calculated at the basic star rates as applicable for the tender, consumed during the quarter under consideration.   | Please consider the base quarter for calculating escalation in the 3rd quarter (October-November-December 2025), taking into account the work situation, as the 4th quarter of 2026 has not yet been published. As per the tender, using the preceding quarter would negatively impact the escalation. | As per NIT.   |         |
| 7     | Page No. 175 | Price Variation Clause | Cement : Rs. 7000/- per MT<br>Reinforcement TMT FE-500 : Rs.61000/- per MT<br>CRS Reinforcement : Rs.63755/- per MT<br>Structural Steel : Rs 62575/- per MT<br>Bitumen VG-10 (Bulk) : Rs 49488/- per MT<br>Bitumen VG-30 (Bulk) : Rs 49862/- per MT | Please provide basic rate for price variation  | As per NIT.<br>The star rates are stipulated in price variation clause and the same shall be applicable for calculation of escalation payment as per price variation clause included in tender documents. |         |

| Sr No   | Page No.     | Ref. Clause No.        | Tender Clause   | Query raised  | MIDC's Reply  | Remarks |
|---|--------------|------------------------|---|---|---|---------|
|   |              |                        | Bitumen emulsion : Rs 40000/- per MT<br>M.S. Plates : Rs.66000/- per MT   |   |   |         |
| <b>M/S Govardhani Construction Co., Navi Mumbai</b> |              |                        |   |   |   |         |
| 1   | Page no. 8   | Scope of work          | The payment against supply of 1800 mm dia MS pipes will be released initially to the extent of maximum 50% quantity under schedule 'B' brought to the site duly inspected and approved by third party inspectors/MIDC. The payment for balance quantity of pipes supplied at site shall be released in proportion to the quantity laid/fixed in position. | It is mentioned on page no. 8/244 under note no. 1 for scope of work that payment for supply of 1800 mm dia M.S. pipe will be released initially to the extent of maximum 50% quantity under schedule B. We also agree that considering large quantity it will not be practical to bring 100% quantity required at single time. In this regard our say is that please revise the star rate of Rs.66,000/- (Rupees Sixty Six Thousand only) given for M.S. plate on page no. 176 as per current /present market rates. Or as per rate issued by Economic Advisor 30 days prior to date of submission, because there is considerable difference and rate considered for star rate is very high and it directly affects the price variation. | As per NIT.   |         |
| 2   | Page no. 230 | Schedule B item no. 36 | Construction of RCC bridge of suitable size across natural stream including hydraulic and geotechnical  | Please provide the details for number of structures/bridges to be constructed (item no.36 of BOQ) with regard to width/length of  | The bridges are required at two locations and the total area of these |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause   | Query raised   | MIDC's Reply   | Remarks |
|-------|----------|-----------------|-----------------|--|--|---------|
|       |          |                 | investigation.. | each bridge, No. of span etc.  | bridges is about 700 Sq.m. The locations and sizes shall be finalized by the contractor by conducting geographical surveys, hydraulic analysis and preparing L sections, which shall be got approved from the competent authority of MIDC.   |         |
| 3     | ---      | ---             | ---             | During site visit it is revealed that last 4 to 5 kilometer new pipeline is to be laid almost parallel to Sambhajinagar to Pune National Highway. In that section whether required land width is available in existing road width reservation to lay this new pipeline or National Highway has to acquire additional width for laying this new pipeline. | It is proposed to lay the part of the pipeline in road land width of Chhatrapati Sambhajinagar-Pune National Highway as permitted by NHAI/PWD. It is responsibility of the contractor to obtain the permission of concerned department. Necessary help will be extended by MIDC & the statutory charges shall be reimbursed by MIDC. |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised  | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|---|---|---------|
|       |          |                 |               | <p>Secondly, particularly in Waluj town within patch of 1.5 to 2 kilometer along MIDC road leading to Bramhagavan, necessary road land width is in possession with MIDC, because in most of the length in this patch existing pipeline and nearby area is encroached by adjoining shops</p> | <p>The pipe Line is proposed to be laid in road land width after removing encroachments. The encroachments existing in the alignment of proposed pipe line shall be removed by contractor at his own cost availing Police protection, if required. MIDC may render suitable assistance for availing Police Protection. However, charges for obtaining Police Protection shall be borne by the contractor. The Pipeline shall be laid as per final approval of NHAI/PWD.</p> |         |
| 4     | ---      | ---             | ---           | <p>It is seen that along MIDC road in almost all length M.S.E.B. has provided electric poles very near to existing pipeline and hence there is no scope to lay a proposed</p>   | <p>The provision for shifting of existing MSEDCL power lines is made in the another tender.</p>   |         |

| Sr No | Page No.  | Ref. Clause No. | Tender Clause   | Query raised   | MIDC's Reply   | Remarks |
|-------|-----------|-----------------|---|--|--|---------|
|       |           |                 |   | <p>pipeline. Whether MIDC has initiated any proposal regarding shifting of these poles so that it will be possible for us to follow up the proposal for approval. Otherwise it will require considerable more time.</p>  |  |         |
| 5     | Page no.7 | Scope of work   | <p>An amount of Rs.16,11,33,333/- or the amount quoted by the bidder for rebate of MS pipes and specials whichever is higher shall be deducted after commissioning of new pipeline.</p> | <p>We hereby request you to reconfirm that the rebate of % 16,11,33,333/- against dismantled pipes and specials will be recovered only after commissioning of new pipeline. Because it is experienced that inspite of specific condition also, accounts department insist on deducting rebate through each RA bill in proportionate to pipeline laid and they do not consider whether existing pipeline is removed or not.</p> | <p>The total length of existing 1050 mm dia M.S. pipeline which can be dismantled is 16200 RM.</p> <p>1.Out of this, the rebate for existing 1050 MS pipes and specials for the length of 12374 RM is Rs.5,51,92,400/-.</p> <p>2.The rebate for 3826 RM length of MS pipeline is Rs.8,40,25,350/-.</p> <p>3.The total rebate amount shall thus be minimum Rs.13,92,17,750/-.</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>The minimum amount to be quoted by the bidders for the rebate shall be Rs.13,92,17,750/-. If the bidder quotes the rebate less than Rs.13,92,17,750/-, MIDC shall revise the offer of the bidder considering minimum rebate amount of Rs.13,92,17,750/- which shall be binding on the bidders. An undertaking on Rs.500/- stamp paper shall be submitted by the bidders stating that MIDC reserves the right to revise the rebate quoted by the bidder to minimum rebate amount of Rs.13,92,17,750/- and the bidder shall not have any objection for the</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>same. This undertaking shall be submitted by the bidders in envelope no.1 else their financial bid shall not be opened.</p> <p>Each and every weighment of dismantled pipes, specials and structural steel shall be done at the cost of the contractor in the presence of MIDC representative and all the weighment slips shall be submitted by the contractor for necessary recovery of the rebate.</p> <p>The recovery of the rebate shall be in proportion to the length of new MS pipeline laid and commissioned.</p> <p>The bidder shall visit the site of</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>work and study the site situation very carefully and quote the amount of rebate accordingly. The amount for rebate of scrap recovered shall be the higher of following.</p> <p>i) <b>The amount quoted by the bidder for rebate of the scrap.</b></p> <p style="text-align: center;"><b>OR</b></p> <p>ii) <b>The amount based on the weight of MS pipes, specials, and structural steel dismantled at the rate of Rs. 30/- per kg for 12,374.00 RM of old pipeline and Rs. 85.50/- per kg for 3826.00 RM of new pipeline, total minimum rebate amounts Rs. 13,92,17,750/-.</b></p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>The existing MS pipes, specials and structural steel shall be dismantled by the contractor after laying, jointing and commissioning the new pipeline within the stipulated contract period as per the directions of MIDC's Engineer-in-Charge and no extra time period over and above the stipulated contract period shall be granted for dismantling of existing old pipe line and specials.</p> <p>The above conditions supersede all the conditions related to the recovery of rebate on account of dismantled M.S. pipes, specials and structural steel</p> |         |

| Sr No   | Page No.       | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply   | Remarks |
|---|----------------|------------------------|---|--|--|---------|
|   |                |                        |   |  | mentioned in the tender documents.   |         |
| 6   | Page no.7      | Scope of work          | An amount of Rs.21,36,000/- is worked out for the job of dewatering. The amount of Rs.21,36,000/- or the amount quoted by the bidder whichever is less shall be paid for dewatering job. No extra claim on account of dewatering over & above Rs.21,36,000/- shall be entertained by MIDC | Dewatering amount is considered on job basis and hence we request you kindly consider to release this job amount quoted in proportionate with M.S. pipeline length laid and jointed.                   | The fixed Lump-sum amount 21,36,000/- or the amount quoted by the bidder for dewatering job, whichever is less shall be paid on job basis in proportion to the length of new MS pipeline laid and jointed. |         |
| 7   | Page no. 9-10  | Scope of work          | The bidder shall submit documents pertaining to owned/leased land of minimum 3.00 acres for stacking of M.S. pipes required for the work at a distance of maximum 5.00 Kms from the alignment of the pipeline within period of one month from date of work order.                         | No doubt we are ready to acquire 3 acres land for stacking pipes within distance of 5 kilometers but whether MIDC can arrange and give more space at WTP & pump house to stack the pipes and material. | As per NIT.  |         |
| <b>(B) Replies to queries received online (on Maha E-Tender website):</b> |                |                        |   |  |  |         |
| <b>1. M/s. Ajwani Infrastructure Private Limited, Mumbai</b>              |                |                        |   |  |  |         |
| 1   | Page No. 3/244 | Detailed Tender Notice | A) Single work of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.8768.30  | The Prequalification criteria specified in tender is not as per MIDC policy norms. we Request MIDC to revise the Similar Work /  | As per NIT.  |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause   | Query raised  | MIDC's Reply | Remarks |
|-------|----------|-----------------|---|---|--------------|---------|
|       |          |                 | <p>Lakhs or Single work of providing, laying and jointing M.S. water supply pipeline having length not less than 8.60 Km and having diameter not less than 900 mm.</p> <p><b>OR</b></p> <p>B) Total cost of two works of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.12275.60 Lakhs or two works of providing, laying and jointing M.S. water supply pipeline having length not less than 12.04 Km and having diameter not less than 900 mm.</p> <p><b>OR</b></p> <p>C) Total cost of three works of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.14029.25 Lakhs or three works of providing, laying and jointing M.S. water supply pipeline having length not less than 13.76 Km and having diameter not less than 900mm.</p> | <p>Experience Criteria in line with MIDC Circular No. CE(HQ)/13/2019 dated 04.07.2019, Clause 14(B) Sr. No. c) (v). The circular clearly specifies that experience for any Water Supply / Sewage / Drainage pipeline work shall be considered with acceptable materials such as CI/MS/DI/HDPE/MDPE/LDPE/GRP/RCC/PSC.</p> <p>Accordingly, we request MIDC to modify the PQ criteria as:</p> <p>Cost of single work of (CI/MS/DI/HDPE/MDPE/LDPE/GRP/RCC/PSC) any pipeline of Water supply / Sewage / Drainage shall not be less than Rs. 8768.30 Lakhs</p> <p><b>OR</b></p> <p>Not less than 900 mm diameter pipeline and 8.60 km length of any single pipeline work of Water supply / Sewage / Drainage. Similarly, two works shall meet the 70% threshold and three works shall meet the 80% threshold, either by cost criteria or by the diameter-length combination in accordance with the MIDC circular</p> <p>C) Total cost of three works of providing, laying and jointing M.S. water supply pipeline costing not</p> |              |         |

| Sr No   | Page No.   | Ref. Clause No. | Tender Clause  | Query raised   | MIDC's Reply   | Remarks |
|---|------------|-----------------|--|--|--|---------|
|   |            |                 |  | less than Rs.14029.25 Lakhs or three works of providing, laying and jointing M.S. water supply pipeline having length not less than 13.76 Km and having diameter not less than 900 mm. |  |         |
| <b>2 Arihant Constructions India Pvt. Ltd. Mumbai</b> |            |                 |  |  |  |         |
| 1   | ---        | ---             | ---  | The queries at Sr. No. 1 to 12 mentioned in letter dated 28.04.2026 from Arihant Constructions India Pvt. Ltd. Mumbai received on Maha E-tender portal.                                | The queries raised by M/S Arihant Constructions India Pvt. Ltd. Mumbai pertain to another work under tender notice No. 02/B/01/2026-27. However, the queries are uploaded on the subject work on Maha E-tender portal. The reply to these queries is provided under relevant tender. |         |
| <b>3. Unkonwn</b>                                     |            |                 |  |  |  |         |
| 1   | Page no. 8 | Scope of work   | The payment against supply of 1800 mm dia MS pipes will be released initially to the extent of maximum 50% quantity under schedule 'B' | It is mentioned on page no. 8/244 under note no. 1 for scope of work that payment for supply of 1800 mm dia M.S. pipe will be released initially to the extent of maximum              | As per NIT   |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause  | Query raised  | MIDC's Reply  | Remarks |
|-------|----------|-----------------|--|---|---|---------|
|       |          |                 | brought to the site duly inspected and approved by third party inspectors/MIDC. The payment for balance quantity of pipes supplied at site shall be released in proportion to the quantity laid/fixed in position. | 50% quantity under schedule B. We also agree that considering large quantity it will not be practical to bring 100% quantity required at single time. In this regard our say is that please revise the star rate of Rs.66,000/- (Rupees Sixty Six Thousand only) given for M.S. plate on page no. 176 as per current /present market rates. Or as per rate issued by Economic Advisor 30 days prior to date of submission, because there is considerable difference and rate considered for star rate is very high and it directly affects the price variation. |   |         |
| 2     | ---      | ---             | ---  | Please provide the details for number of structures/bridges to be constructed (item no.36 of BOQ) with regard to width/length of each bridge, No. of span etc.  | The bridges are required at two locations and the total area of these bridges is about 700 Sq.m. The locations and sizes shall be finalized by the contractor by conducting geographical surveys, hydraulic analysis and preparing L sections, which shall be got |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised  | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|---|--|---------|
|       |          |                 |               |   | approved from the competent authority of MIDC.   |         |
| 3     | ---      | ---             | ---           | <p>During site visit it is revealed that last 4 to 5 kilometer new pipeline is to be laid almost parallel to Sambhajinagar to Pune National Highway. In that section whether required land width is available in existing road width reservation to lay this new pipeline or National Highway has to acquire additional width for laying this new pipeline.</p> <p>Secondly, particularly in Waluj town within patch of 1.5 to 2 kilometer along MIDC road leading to Bramhagavan, necessary road land width is in possession with MIDC, because in most of the length in this patch existing</p> | <p>It is proposed to lay the part of the pipeline in road land width of Chhatrapati Sambhajinagar-Pune National Highway as permitted by NHAI/PWD. It is responsibility of the contractor to obtain the permission of concerned department. Necessary help will be extended by MIDC &amp; the statutory charges shall be reimbursed by MIDC.</p> <p>The pipe Line is proposed to be laid in road land width after removing encroachments. The encroachments existing in the</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised  | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|---|---|---------|
|       |          |                 |               | pipeline and nearby area is encroached by adjoining shops   | <p>alignment of proposed pipe line shall be removed by contractor at his own cost availing Police protection, if required. MIDC may render suitable assistance for availing Police Protection.</p> <p>However, charges for obtaining Police Protection shall be borne by the contractor.</p> <p>The Pipeline shall be laid as per final approval of NHAI/PWD.</p> |         |
| 4     | ---      | ---             | ---           | It is seen that along MIDC road in almost all length M.S.E.B. has provided electric poles very near to existing pipeline and hence there is no scope to lay a proposed pipeline. Whether MIDC has initiated any proposal regarding shifting of these poles so that it will be possible for us to follow up the proposal for approval. Otherwise it will require considerable more time. | The provision for shifting of MSEDCL power lines is made in the another tender.   |         |

| Sr No | Page No.  | Ref. Clause No. | Tender Clause  | Query raised  | MIDC's Reply   | Remarks |
|-------|-----------|-----------------|--|---|--|---------|
| 5     | Page no.7 | Scope of work   | An amount of Rs.16,11,33,333/- or the amount quoted by the bidder for rebate of MS pipes and specials whichever is higher shall be deducted after commissioning of new pipeline. | We hereby request you to reconfirm that the rebate of % 16,11,33,333/- against dismantled pipes and specials will be recovered only after commissioning of new pipeline. Because it is experienced that inspite of specific condition also, accounts department insist on deducting rebate through each RA bill in proportionate to pipeline laid and they do not consider whether existing pipeline is removed or not. | <p>The total length of existing 1050 mm dia M.S. pipeline which can be dismantled is 16200 RM.</p> <p>1.Out of this, the rebate for existing 1050 MS pipes and specials for the length of 12374 RM is Rs.5,51,92,400/-.</p> <p>2.The rebate for 3826 RM length of MS pipeline is Rs.8,40,25,350/-.</p> <p>3.The total rebate amount shall thus be minimum Rs.13,92,17,750/-.</p> <p>The minimum amount to be quoted by the bidders for the rebate shall be Rs.13,92,17,750/-.</p> <p>If the bidder quotes the rebate</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>less than Rs.13,92,17,750/-, MIDC shall revise the offer of the bidder considering minimum rebate amount of Rs.13,92,17,750/- which shall be binding on the bidders. An undertaking on Rs.500/- stamp paper shall be submitted by the bidders stating that MIDC reserves the right to revise the rebate quoted by the bidder to minimum rebate amount of Rs.13,92,17,750/- and the bidder shall not have any objection for the same. This undertaking shall be submitted by the bidders in envelope no.1 else their financial bid shall not</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>be opened.</p> <p>Each and every weighment of dismantled pipes, specials and structural steel shall be done at the cost of the contractor in the presence of MIDC representative and all the weighment slips shall be submitted by the contractor for necessary recovery of the rebate.</p> <p>The recovery of the rebate shall be in proportion to the length of new MS pipeline laid and commissioned.</p> <p>The bidder shall visit the site of work and study the site situation very carefully and quote the amount of rebate accordingly. The amount for rebate of</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>scrap recovered shall be the higher of following.</p> <p>i) <b>The amount quoted by the bidder for rebate of the scrap.</b></p> <p style="text-align: center;"><b>OR</b></p> <p>ii) <b>The amount based on the weight of MS pipes, specials, and structural steel dismantled at the rate of Rs. 30/- per kg for 12,374.00 RM of old pipeline and Rs. 85.50/- per kg for 3826.00 RM of new pipeline, total minimum rebate amounts Rs. 13,92,17,750/-.</b></p> <p>The existing MS pipes, specials and structural steel shall be dismantled by the contractor after laying, jointing and commissioning</p> |         |

| Sr No | Page No.  | Ref. Clause No. | Tender Clause   | Query raised   | MIDC's Reply  | Remarks |
|-------|-----------|-----------------|---|--|---|---------|
|       |           |                 |   |  | <p>the new pipeline within the stipulated contract period as per the directions of MIDC's Engineer-in-Charge and no extra time period over and above the stipulated contract period shall be granted for dismantling of existing old pipe line and specials.</p> <p>The above conditions supersede all the conditions related to the recovery of rebate on account of dismantled M.S. pipes, specials and structural steel mentioned in the tender documents.</p> |         |
| 6     | Page no.7 | Scope of work   | An amount of Rs.21,36,000/- is worked out for the job of dewatering. The amount of Rs.21,36,000/- or the amount quoted by the bidder whichever is less shall be | Dewatering amount is considered on job basis and hence we request you kindly consider to release this job amount quoted in proportionate with M.S. pipeline length laid and jointed. | The fixed Lump-sum amount 21,36,000/- or the amount quoted by the bidder for dewatering job,  |         |

| Sr No | Page No.      | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply  | Remarks |
|-------|---------------|------------------------|---|--|---|---------|
|       |               |                        | paid for dewatering job. No extra claim on account of dewatering over & above Rs.21,36,000/- shall be entertained by MIDC   |  | whichever is less shall be paid on job basis in proportion to the length of new MS pipeline laid and jointed.                             |         |
| 7     | Page no. 9-10 | Scope of work          | The bidder shall submit documents pertaining to owned/leased land of minimum 3.00 acres for stacking of M.S. pipes required for the work at a distance of maximum 5.00 Kms from the alignment of the pipeline within period of one month from date of work order. | No doubt we are ready to acquire 3 acres land for stacking pipes within distance of 5 kilometers but whether MIDC can arrange and give more space at WTP & pump house to stack the pipes and material.   | As per NIT.   |         |
| 8     | Page No. 233  | Schedule B Item No. 47 | Providing flush grooved pointing with cement mortar 1:3 for stone masonry work including scaffolding and curing etc. complete.<br>Unit – Square Kilometer   | Item No.47 of BOQ on Page No.233/244, the unit for flush grooved pointing is square kilometre please change it to square meter.  | The Unit of item no. 47 of "Schedule B" of the subject work (pointing work) shall be read as Sq.m instead of Square kilometer.            |         |
| 9     | Page no.7     | Scope of work          | An amount of Rs. Rs.16,11,33,333/- is worked out as rebate value for dismantled MS pipes and specials.  | The amount of Rebate for dismantled MS pipes and specials for Rs.16,11,33,333/- is very much higher side and hence seems to be not economical. You are requested to reduce the amount of Rebate with regards to current market rate for scrap, otherwise allow us to | The total length of existing 1050 mm dia M.S. pipeline which can be dismantled is 16200 RM.<br><br>1.Out of this, the rebate for existing |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised   | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--|---|---------|
|       |          |                 |               | deposit dismantle pipes & specials to MIDC godown/store. | <p>1050 MS pipes and specials for the length of 12374 RM is Rs.5,51,92,400/-.</p> <p>2.The rebate for 3826 RM length of MS pipeline is Rs.8,40,25,350/-.</p> <p>3.The total rebate amount shall thus be minimum Rs.13,92,17,750/-.</p> <p>The minimum amount to be quoted by the bidders for the rebate shall be Rs.13,92,17,750/-. If the bidder quotes the rebate less than Rs.13,92,17,750/-, MIDC shall revise the offer of the bidder considering minimum rebate amount of Rs.13,92,17,750/- which shall be binding on the bidders. An</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>undertaking on Rs.500/- stamp paper shall be submitted by the bidders stating that MIDC reserves the right to revise the rebate quoted by the bidder to minimum rebate amount of Rs.13,92,17,750/- and the bidder shall not have any objection for the same. This undertaking shall be submitted by the bidders in envelope no.1 else their financial bid shall not be opened.</p> <p>Each and every weighing of dismantled pipes, specials and structural steel shall be done at the cost of the contractor in the presence of MIDC representative and all</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>the weighment slips shall be submitted by the contractor for necessary recovery of the rebate.</p> <p>The recovery of the rebate shall be in proportion to the length of new MS pipeline laid and commissioned.</p> <p>The bidder shall visit the site of work and study the site situation very carefully and quote the amount of rebate accordingly. The amount for rebate of scrap recovered shall be the higher of following.</p> <p><b>i) The amount quoted by the bidder for rebate of the scrap.</b></p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p style="text-align: center;"><b>OR</b></p> <p><b>ii) The amount based on the weight of MS pipes, specials, and structural steel dismantled at the rate of Rs. 30/- per kg for 12,374.00 RM of old pipeline and Rs. 85.50/- per kg for 3826.00 RM of new pipeline, total minimum rebate amounts Rs. 13,92,17,750/-.</b></p> <p>The existing MS pipes, specials and structural steel shall be dismantled by the contractor after laying, jointing and commissioning the new pipeline within the stipulated contract period as per the directions of MIDC's Engineer-in-Charge and no extra time period over and</p> |         |

| Sr No  | Page No.  | Ref. Clause No. | Tender Clause   | Query raised  | MIDC's Reply  | Remarks |
|--|-----------|-----------------|---|---|---|---------|
|  |           |                 |   |   | <p>above the stipulated contract period shall be granted for dismantling of existing old pipe line and specials.</p> <p>The above conditions supersede all the conditions related to the recovery of rebate on account of dismantled M.S. pipes, specials and structural steel mentioned in the tender documents.</p> |         |
| <b>(C) Replies to queries raised during pre-bid meeting:</b>                                       |           |                 |   |   |   |         |
| 1) NP Infraprojects India Pvt. Ltd., Chhtrapati Sambhajanagar (Received via E-mail on. 29.04.2026) |           |                 |   |   |   |         |
| 1  | Page no.7 | Scope of work   | An amount of Rs. 16,11,33,333/- is worked out as rebate value for dismantled MS pipes and specials. | Revise this value suitably considering age of old line depreciated value also deducting length in encased portions & deep water arrears. Ideally it comes to the tune of 50% of asked value | <p>The total length of existing 1050 mm dia M.S. pipeline which can be dismantled is 16200 RM.</p> <p>1.Out of this, the rebate for existing</p>  |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>1050 MS pipes and specials for the length of 12374 RM is Rs.5,51,92,400/-.</p> <p>2.The rebate for 3826 RM length of MS pipeline is Rs.8,40,25,350/-.</p> <p>3.The total rebate amount shall thus be minimum Rs.13,92,17,750/-.</p> <p>The minimum amount to be quoted by the bidders for the rebate shall be Rs.13,92,17,750/-. If the bidder quotes the rebate less than Rs.13,92,17,750/-, MIDC shall revise the offer of the bidder considering minimum rebate amount of Rs.13,92,17,750/- which shall be binding on the bidders. An</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>undertaking on Rs.500/- stamp paper shall be submitted by the bidders stating that MIDC reserves the right to revise the rebate quoted by the bidder to minimum rebate amount of Rs.13,92,17,750/- and the bidder shall not have any objection for the same. This undertaking shall be submitted by the bidders in envelope no.1 else their financial bid shall not be opened.</p> <p>Each and every weighing of dismantled pipes, specials and structural steel shall be done at the cost of the contractor in the presence of MIDC representative and all</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>the weighthment slips shall be submitted by the contractor for necessary recovery of the rebate.</p> <p>The recovery of the rebate shall be in proportion to the length of new MS pipeline laid and commissioned.</p> <p>The bidder shall visit the site of work and study the site situation very carefully and quote the amount of rebate accordingly. The amount for rebate of scrap recovered shall be the higher of following.</p> <p>i) <b>The amount quoted by the bidder for rebate of the scrap.</b></p> <p><b>OR</b></p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>ii) The amount based on the weight of MS pipes, specials, and structural steel dismantled at the rate of Rs. 30/- per kg for 12,374.00 RM of old pipeline and Rs. 85.50/- per kg for 3826.00 RM of new pipeline, total minimum rebate amounts Rs. <b>13,92,17,750/-</b>.</p> <p>The existing MS pipes, specials and structural steel shall be dismantled by the contractor after laying, jointing and commissioning the new pipeline within the stipulated contract period as per the directions of MIDC's Engineer-in-Charge and no extra time period over and above the stipulated</p> |         |

| Sr No | Page No.     | Ref. Clause No.        | Tender Clause   | Query raised  | MIDC's Reply   | Remarks |
|-------|--------------|------------------------|---|---|--|---------|
|       |              |                        |   |   | <p>contract period shall be granted for dismantling of existing old pipe line and specials.</p> <p>The above conditions supersede all the conditions related to the recovery of rebate on account of dismantled M.S. pipes, specials and structural steel mentioned in the tender documents.</p> |         |
| 2     | Page No. 171 | Price Variation Clause | <p>Formula for Materials components:</p> $V2 = 0.85P \times \left( \frac{100}{M0} \right) \times (M1 - M0)$ | Adopt formula for piece variation MS pipes as quantity X rate difference of MILD steel plates i.e. quantity = (Rate at procurement as per SAIL Star rate) | As per NIT.  |         |
| 3     | ---          | ---                    | ---   | Alignment plan not given<br>Please Provide  | The Alignment plan of the proposed pipeline is attached as per Annexure-II.  |         |
| 4     | Page no. 8   | Scope of work          | The payment against supply of 1800 mm dia MS pipes will   | Tender condition for supply of pipe. Its limited to 50% supply then   | As per NIT.  |         |

| Sr No | Page No.      | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply   | Remarks |
|-------|---------------|------------------------|---|--|--|---------|
|       |               |                        | be released initially to the extent of maximum 50% quantity under schedule 'B' brought to the site duly inspected and approved by third party inspectors/MIDC. The payment for balance quantity of pipes supplied at site shall be released in proportion to the quantity laid/fixed in position. | supply as per laying & jointing. No conditions as contractor can supply more qty also, this will not attract any further rate increase factor and speed of work will ok.                         |  |         |
| 5     | Page no. 218  | Schedule B item no. 11 | Dewatering the excavated trenches and pools of water in the building trenches / pipeline trenches ..<br>Unit - Job  | Dewatering<br>Max amt is Rs. 21,36,000/-<br>To be actual BHP/HR basis  | The fixed Lump-sum amount 21,36,000/- or the amount quoted by the bidder for dewatering job, whichever is less shall be paid on job basis in proportion to the length of new MS pipeline laid and jointed. |         |
| 6     | Page no. 9-10 | Scope of work          | The bidder shall submit documents pertaining to owned/leased land of minimum 3.00 acres for stacking of M.S. pipes required for the work at a   | Land for stocking pipes- 5 Acre land to be rented / own by contractor within 5 km from site area or Rs. 2.0 lakh / month recovery will be done. Better to provide land form Govt sources near by | As per NIT   |         |

| Sr No   | Page No.   | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply | Remarks |
|---|------------|------------------------|---|--|--------------|---------|
|   |            |                        | distance of maximum 5.00 Kms from the alignment of the pipeline within period of one month from date of work order..  |  |              |         |
| 7   | Page no. 3 | Detailed Tender Notice | Time period - 24 months including monsoon   | 36 months including monsoon  | As per NIT.  |         |
| 2) Patel Engineering, Mumbai (Received via E-mail on. 30.04.2026) |            |                        |   |  |              |         |
| 1   | Page no. 3 | Detailed Tender Notice | The UNREGISTERED/ REGISTERED civil contractors having registration in appropriate class with PWD, Govt, of Maharashtra/CPWD/MES/Railways/CIDCO/MJP and having experience certificate of works completed in all respects detailed as below in any Government/Semi. Govt./Local bodies executed during any of last five financial years and signed by an offices not below the rank of Executive Engineer<br>A)Single work of providing, laying and jointing MS water supply pipeline costing not less than Rs. 8768.30 lakhs or single work of providing, laying and jointing MS water supply pipeline having length | It is necessary to complete the work 100% or substantially completed with fulfill of above requirement only. | As per NIT.  |         |

| Sr No   | Page No.  | Ref. Clause No. | Tender Clause   | Query raised  | MIDC's Reply   | Remarks |
|---|-----------|-----------------|---|---|--|---------|
|   |           |                 | not less than 8.60 Km and having diameter not less than 900 mm.                                     |   |  |         |
| 3) Hrishikesh Group, Chhtrapati Sambhajinagar (Received via E-mail on 29.04.2026) |           |                 |   |   |  |         |
| 1   | Page no.7 | Scope of work   | An amount of Rs. 16,11,33,333/- is worked out as rebate value for dismantled MS pipes and specials. | Revise this value suitably considering age of old line depreciated value also deducting length in encased portions & deep water arrears. Ideally it comes to the tune of 50% of asked value | <p>The total length of existing 1050 mm dia M.S. pipeline which can be dismantled is 16200 RM.</p> <p>1.Out of this, the rebate for existing 1050 MS pipes and specials for the length of 12374 RM is Rs.5,51,92,400/-.</p> <p>2.The rebate for 3826 RM length of MS pipeline is Rs.8,40,25,350/-.</p> <p>3.The total rebate amount shall thus be minimum Rs.13,92,17,750/-.</p> <p>The minimum amount to be quoted by the bidders for the rebate shall be</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>Rs.13,92,17,750/- . If the bidder quotes the rebate less than Rs.13,92,17,750/-, MIDC shall revise the offer of the bidder considering minimum rebate amount of Rs.13,92,17,750/- which shall be binding on the bidders. An undertaking on Rs.500/- stamp paper shall be submitted by the bidders stating that MIDC reserves the right to revise the rebate quoted by the bidder to minimum rebate amount of Rs.13,92,17,750/- and the bidder shall not have any objection for the same. This undertaking shall be submitted by the bidders in envelope</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>no.1 else their financial bid shall not be opened.</p> <p>Each and every weighment of dismantled pipes, specials and structural steel shall be done at the cost of the contractor in the presence of MIDC representative and all the weighment slips shall be submitted by the contractor for necessary recovery of the rebate.</p> <p>The recovery of the rebate shall be in proportion to the length of new MS pipeline laid and commissioned.</p> <p>The bidder shall visit the site of work and study the site situation very carefully and quote the amount of rebate</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>accordingly. The amount for rebate of scrap recovered shall be the higher of following.</p> <p>i) <b>The amount quoted by the bidder for rebate of the scrap.</b></p> <p style="text-align: center;"><b>OR</b></p> <p>ii) <b>The amount based on the weight of MS pipes, specials, and structural steel dismantled at the rate of Rs. 30/- per kg for 12,374.00 RM of old pipeline and Rs. 85.50/- per kg for 3826.00 RM of new pipeline, total minimum rebate amounts Rs. 13,92,17,750/-.</b></p> <p>The existing MS pipes, specials and structural steel shall be dismantled by the contractor</p> |         |

| Sr No | Page No.     | Ref. Clause No.        | Tender Clause  | Query raised   | MIDC's Reply   | Remarks |
|-------|--------------|------------------------|--|--|--|---------|
|       |              |                        |  |  | <p>after laying, jointing and commissioning the new pipeline within the stipulated contract period as per the directions of MIDC's Engineer-in-Charge and no extra time period over and above the stipulated contract period shall be granted for dismantling of existing old pipe line and specials.</p> <p>The above conditions supersede all the conditions related to the recovery of rebate on account of dismantled M.S. pipes, specials and structural steel mentioned in the tender documents.</p> |         |
| 2     | Page No. 171 | Price Variation Clause | Formula for Materials components:<br>$V2 = 0.85P \times (K2)$<br>----- | Adopt formula for piece variation MS pipes as quantity X rate difference of MILD steel plates i.e. quantity= (Rate at procurement as | As per NIT.  |         |

| Sr No | Page No.     | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply  | Remarks |
|-------|--------------|------------------------|---|--|---|---------|
|       |              |                        | 100<br>X (M1-M0)<br>-----<br>M0   | per SAIL Star rate)  |   |         |
| 3     | ---          | ---                    | ---   | Alignment plan not given<br>Please Provide   | The Alignment plan of the proposed pipeline is attached as per Annexure-II.   |         |
| 4     | Page no. 8   | Scope of work          | The payment against supply of 1800 mm dia MS pipes will be released initially to the extent of maximum 50% quantity under schedule 'B' brought to the site duly inspected and approved by third party inspectors/MIDC. The payment for balance quantity of pipes supplied at site shall be released in proportion to the quantity laid/fixed in position. | Tender condition for supply of pipe. Its limited to 50% supply then supply as per laying & jointing. No conditions as contractor can supply more qty also, this will not attract any further rate increase factor and speed of work will ok. | As per NIT.   |         |
| 5     | Page no. 218 | Schedule B item no. 11 | Dewatering the excavated trenches and pools of water in the building trenches / pipeline trenches ..<br>Unit - Job  | Dewatering<br>Max amt is Rs. 21,36,000/-<br>To be actual BHP/HR basis  | The fixed Lump-sum amount 21,36,000/- or the amount quoted by the bidder for dewatering job, whichever is less shall be paid on job basis in proportion to the length of new MS pipeline laid and |         |

| Sr No   | Page No.      | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply   | Remarks |
|---|---------------|------------------------|---|--|--|---------|
|   |               |                        |   |  | jointed.   |         |
| 6   | Page no. 9-10 | Scope of work          | The bidder shall submit documents pertaining to owned/leased land of minimum 3.00 acres for stacking of M.S. pipes required for the work at a distance of maximum 5.00 Kms from the alignment of the pipeline within period of one month from date of work order. | Land for stocking pipes- 5 Acre land to be rented / own by contractor within 5 km from site area or Rs. 2.0 lakh / month recovery will be done. Better to provide land form Govt sources near by | As per NIT.  |         |
| 7   | Page no. 3    | Detailed Tender Notice | Time period - 24 months including monsoon   | 36 months including monsoon  | As per NIT.  |         |
| 4) Akash Construction (Received via E-mail on 29.04.2026) |               |                        |   |  |  |         |
| 1   | Page no.7     | Scope of work          | An amount of Rs. 16,11,33,333/- is worked out as rebate value for dismantled MS pipes and specials.   | Revise this value suitably considering age of old line depreciated value also deducting length in encased portions & deep water arrears. Ideally it comes to the tune of 50% of asked value      | <p>The total length of existing 1050 mm dia M.S. pipeline which can be dismantled is 16200 RM.</p> <p>1.Out of this, the rebate for existing 1050 MS pipes and specials for the length of 12374 RM is Rs.5,51,92,400/-.</p> <p>2.The rebate for 3826 RM length of MS pipeline is</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>Rs.8,40,25,350/-.</p> <p>3.The total rebate amount shall thus be minimum<br/>Rs.13,92,17,750/-.</p> <p>The minimum amount to be quoted by the bidders for the rebate shall be Rs.13,92,17,750/-. If the bidder quotes the rebate less than Rs.13,92,17,750/-, MIDC shall revise the offer of the bidder considering minimum rebate amount of Rs.13,92,17,750/- which shall be binding on the bidders. An undertaking on Rs.500/- stamp paper shall be submitted by the bidders stating that MIDC reserves the right to revise the rebate quoted by the bidder to minimum</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>rebate amount of Rs.13,92,17,750/- and the bidder shall not have any objection for the same. This undertaking shall be submitted by the bidders in envelope no.1 else their financial bid shall not be opened.</p> <p>Each and every weighment of dismantled pipes, specials and structural steel shall be done at the cost of the contractor in the presence of MIDC representative and all the weighment slips shall be submitted by the contractor for necessary recovery of the rebate.</p> <p>The recovery of the rebate shall be in proportion to the</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>length of new MS pipeline laid and commissioned.</p> <p>The bidder shall visit the site of work and study the site situation very carefully and quote the amount of rebate accordingly. The amount for rebate of scrap recovered shall be the higher of following.</p> <p><b>i) The amount quoted by the bidder for rebate of the scrap.</b></p> <p style="text-align: center;"><b>OR</b></p> <p><b>ii) The amount based on the weight of MS pipes, specials, and structural steel dismantled at the rate of Rs. 30/- per kg for 12,374.00 RM of old pipeline and Rs. 85.50/- per kg</b></p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p><b>for 3826.00 RM of new pipeline, total minimum rebate amounts Rs. 13,92,17,750/-.</b></p> <p>The existing MS pipes, specials and structural steel shall be dismantled by the contractor after laying, jointing and commissioning the new pipeline within the stipulated contract period as per the directions of MIDC's Engineer-in-Charge and no extra time period over and above the stipulated contract period shall be granted for dismantling of existing old pipe line and specials.</p> <p>The above conditions supersede all the conditions related to the recovery of</p> |         |

| Sr No | Page No.     | Ref. Clause No.        | Tender Clause  | Query raised   | MIDC's Reply   | Remarks |
|-------|--------------|------------------------|--|--|--|---------|
|       |              |                        |  |  | rebate on account of dismantled M.S. pipes, specials and structural steel mentioned in the tender documents. |         |
| 2     | Page No. 171 | Price Variation Clause | Formula for Materials components:<br>$V2 = 0.85P \times \left( \frac{K2}{100} \right) \times (M1 - M0)$  | Adopt formula for piece variation MS pipes as quantity X rate difference of MILD steel plates i.e. quantity= (Rate at procurement as per SAIL Star rate)   | As per NIT.  |         |
| 3     | ---          | ---                    | ---  | Alignment plan not given<br>Please Provide   | The Alignment plan of the proposed pipeline is attached as per Annexure-II.                                  |         |
| 4     | Page no. 8   | Scope of work          | The payment against supply of 1800 mm dia MS pipes will be released initially to the extent of maximum 50% quantity under schedule 'B' brought to the site duly inspected and approved by third party inspectors/MIDC. The payment for balance quantity of pipes supplied at | Tender condition for supply of pipe. Its limited to 50% supply then supply as per laying & jointing. No conditions as contractor can supply more qty also, this will not attract any further rate increase factor and speed of work will ok. | As per NIT.  |         |

| Sr No   | Page No.      | Ref. Clause No.        | Tender Clause  | Query raised   | MIDC's Reply  | Remarks |
|---|---------------|------------------------|--|--|---|---------|
|   |               |                        | site shall be released in proportion to the quantity laid/fixed in position.   |  |   |         |
| 5   | Page no. 218  | Schedule B item no. 11 | Dewatering the excavated trenches and pools of water in the building trenches / pipeline trenches ..<br>Unit - Job   | Dewatering<br>Max amt is Rs. 21,36,000/-<br>To be actual BHP/HR basis  | The fixed Lump-sum amount 21,36,000/- or the amount quoted by the bidder for dewatering job, whichever is less shall be paid on job basis in proportionate to the length of new MS pipeline laid and jointed. |         |
| 6   | Page no. 9-10 | Scope of work          | The bidder shall submit documents pertaining to owned/leased land of minimum 3.00 acres for stacking of M.S. pipes required for the work at a distance of maximum 5.00 Kms from the alignment of the pipeline within period of one month from date of work order.. | Land for stocking pipes- 5 Acre land to be rented / own by contractor within 5 km from site area or Rs. 2.0 lakh / month recovery will be done. Better to provide land form Govt sources near by | AS Per NIT.   |         |
| 7   | Page no. 3    | Detailed Tender Notice | Time period - 24 months including monsoon  | 36 months including monsoon  | As per NIT.   |         |
| 5) Jaidepraj Infrastructure Private Limited, Mumbai (Received via E-mail on 29.04.2026) |               |                        |  |  |   |         |

| Sr No | Page No.   | Ref. Clause No.        | Tender Clause   | Query raised  | MIDC's Reply | Remarks |
|-------|------------|------------------------|---|---|--------------|---------|
| 1     | Page No. 3 | Detailed Tender Notice | <p>A) Single work of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.8768.30 Lakhs or Single work of providing, laying and jointing M.S. water supply pipeline having length not less than 8.60 Km and having diameter not less than 900 mm.</p> <p><b>OR</b></p> <p>B) Total cost of two works of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.12275.60 Lakhs or two works of providing, laying and jointing M.S. water supply pipeline having length not less than 12.04 Km and having diameter not less than 900 mm.</p> <p><b>OR</b></p> <p>C) Total cost of three works of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.14029.25 Lakhs or three works of providing, laying and jointing M.S. water supply pipeline having length not less than 13.76 Km and</p> | <p>On page No.03 in details Tender Notice under Column No.19 eligibility criteria is mentioned that Single work of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.8768.30 Lakhs or Single work of providing, laying and jointing M.S. water supply pipeline having length not less than 8.60 Km and having diameter not less than 900 mm and so on. In this regard it is requested to please carry out the minor changes in eligibility criteria as per Pen-Alibaug Tender Notice No.128 of 2023-24, DG Lote Parshuram Tender, Dherand Shahpur Tender Notice No.62 of 2025-26 i.e. cost of Single work of any pipe line of water supply/ sewage/ drainage shall not be less than Rs..... lakhs instead of providing, laying and jointing M.S.water supply pipeline costing not less than Rs..... or not less than .....mm diameter and having total length more than .....km of any pipeline of water supply/sewage/drainage instead of Single work of providing, laying and jointing M.S. water supply pipeline having length not less than 8.60</p> | As per NIT.  |         |

| Sr No | Page No.   | Ref. Clause No.        | Tender Clause   | Query raised  | MIDC's Reply   | Remarks |
|-------|------------|------------------------|---|---|--|---------|
|       |            |                        | having diameter not less than 900mm.  | Km and having diameter not less than 900 mm and so on.  |  |         |
| 2     | Page No. 3 | Detailed Tender Notice | GEO Tagging Schedule date (As per MIDC Circular No.1, dated 09/01/2023)   | On page no.3 in details Tender Notice under Column No.15 it is mentioned that, Geo Tagging Schedule Date (As per MIDC Circular No.1, dtd. 09.01.2023), but the date of Geo Tagging has not been mentioned. However, please clarify that for this work, the contractor is required to do Geo Tagging or otherwise? Also if Geo Tagging is necessary, by which date geo tagging needs to be done by contractor please clarify.  | Geo Tagging shall not be applicable for this tender.   |         |
| 3     | Page no. 9 | Scope of work          | Contractor shall provide one four-wheeler air-conditioned new INNOVA car in good condition for inspection of work as and when required throughout the contract period. Necessary fuel & driver shall be provided by contractor at his own cost. The vehicle shall be provided from date of actual start of work to the actual date of completion. Otherwise MIDC will engage vehicle from local market & necessary rental | On Page No. 9 Point No.17 of the tender It is stated that Contractor shall provide one four-wheeler air-conditioned new INNOVA car in good condition for inspection of work as and when required throughout the contract period. Necessary fuel & driver shall be provided by contractor at his own cost. The vehicle shall be provided from date of actual start of work to the actual date of completion. Otherwise MIDC will engage vehicle from local market & necessary rental charges will be | The rates shall be quoted by agency inclusive of providing a new INNOVA car in good condition for inspection of work as and when required throughout the contract period. No separate payment for providing car shall be made. The bidders shall quote |         |

| Sr No | Page No.    | Ref. Clause No.     | Tender Clause   | Query raised   | MIDC's Reply  | Remarks |
|-------|-------------|---------------------|---|--|---|---------|
|       |             |                     | charges will be recovered from each RA bill. The maintenance of the vehicle shall be done by the agency at his own cost. The vehicle shall be property of the agency after completion of work.      | recovered from each RA bill. The maintenance of the vehicle shall be done by the agency at his own cost. The vehicle shall be property of the agency after completion of work. In this regard, it is noted that, as per the tender specifications, the stipulated period for the execution of the said work is 24 months; however, no provision has been made in Schedule-B of this tender to cover the expenses associated with deploying a four-wheeled, air-conditioned INNOVA car at the work site for this duration, as required by the relevant clause. Therefore, it is necessary to clarify whether the costs incurred for the four-wheeled vehicle will be incorporated into the evaluated cost of the work under this scheme and whether the contractor's bid will subsequently be compared against this revised evaluated cost. | their offers accordingly.   |         |
| 4     | Page No. 35 | Preparation of Bids | Certificate from PWD authority regarding fitness and location of Asphalt plant. If the asphalt plant is not within 50 kms. from site of work, the tenderer will have to pay the deposit for asphalt | On page no.35 Issue No 11.1 D states that Certificate from PWD authority regarding fitness and location of Asphalt Plant. If the asphalt plant is not within 50 Kms. From site of work, the tenderer will have to pay the deposit online. As   | Hot Mix Plant shall not be required for this work. Hence, DD and Undertaking regarding Hot mix plant shall not be required. |         |

| Sr No | Page No.   | Ref. Clause No. | Tender Clause   | Query raised  | MIDC's Reply                        | Remarks |
|-------|------------|-----------------|---|---|-------------------------------------|---------|
|       |            |                 | <p>plant online. The document of ownership or rent agreement of plant shall be enclosed as specified and undertaking for shifting of asphalt plant within 50 km before one month of start of asphalt work.. (If Asphalt condition applicable)</p> | <p>well as page no. 40 in PQ Form D Issue No. 2 states that In case if the contractor do not possess-hot mix as per plant within 51 km radius strong site of work, than and undertaking on Stamp Paper of Rs.500/- duly notarized shall be submitted by the contractor along with PQ Form in envelope No.1 for assurance towards erection of hot mix as per plant within 50 km from the site of work not later than 1 month from the date of work order, and separate amount of Rs.5,00,000/- as guarantee shall be submitted along with PQ Form in envelope no.1. Once the contractor erects the hot mix plant, within 50 km radius from site work, the amount of Rs.5,00,000/- will be refunded. However, since asphalting is not included in Schedule-B of this tender, we are of the view that Hot Mix Plant will not be required for this work. Therefore, since the above mentioned conditions are not applicable to this tender, it is requested to delete these conditions.</p> |                                     |         |
| 5     | Page no. 8 | Scope of work   | The agency should construct a site office of area specified   | On page no.8 point No.2 it is stated that The Agency should construct a   | The rates shall be quoted by agency |         |

| Sr No | Page No.           | Ref. Clause No.        | Tender Clause   | Query raised  | MIDC's Reply   | Remarks |
|-------|--------------------|------------------------|---|---|--|---------|
|       |                    |                        | in the tender at the work site for use of MIDC Engineers & other staff with 1 table, 6 chairs, 1 steel cupboard, 1 fan, 1 latest computer and printer etc. without any claim for reimbursement, otherwise an amount of Rs.2.00 Lakhs shall be deducted from 1st RA Bill. The computer and printer provided by the contractor shall be absolutely the property of MIDC after completion of work. | site office of area specified in the Tender at the work site for used of MIDC engineers and other Staff with One Table, 6 Chairs, 1 Steel Cupboard, 1 Fan, 1 Latest Computer and Printer without any claim for reimbursement, otherwise and amount of Rs.2 Lakhs shall be deducted from 1st RA Bill. The Computer and Printer provided by the Contractor shall be absolutely the property of MIDC after completion of work. Since both these conditions regarding the site office are inconsistent, it is necessary to clarify how the actual site office is to be constructed. If a computer, printer are to be supplied for this office, the cost incurred by the contractor for the same should be included in the evaluated price of this tender and it is necessary to compare the contractor's price with that price. So, we request you to clarify this. | inclusive of constructing site office with furniture. The furniture along with Computer and Printer shall be the property of contractor after completion of work. No separate payment shall be made for construction of site office and providing furniture along with computer and printer. The bidders shall quote their offers accordingly. |         |
| 6     | Page no. 124 & 222 | Schedule B item No. 19 | Welding in all positions with required number of runs, for M. S. pipes internally and / or externally including gauging wherever necessary, fixing appurtenances and other accessories in connection  | On page no.124, provision has been made regarding welding in item no.19 and it is necessary to clarify whether the said provision of welding is for Butt Joint or Lap Joint? Please Clarify.  | The item is inclusive of all types of welding.   |         |

| Sr No | Page No.           | Ref. Clause No.        | Tender Clause   | Query raised   | MIDC's Reply  | Remarks |
|-------|--------------------|------------------------|---|--|---|---------|
|       |                    |                        | with pipe laying work as per specification.   |  |   |         |
| 7     | Page no. 133 & 231 | Schedule B item No. 38 | Approved various diameter mild steel (M.S) pipe etc. complete as per specifications and as directed by the Engineer. 2000 mm dia & 22mm thick   | On page no.133 under item no.38, provision has been made for supply of mild steel pipes of 2000 mm. diameter & 22 mm thick. However, this tender does not appear to provide for laying of mild steel pipes of 2000 mm diameter. It is requested to clarify whether the said pipes are to be laid or not and if they are to be laid, necessary provisions are made in the tender. | The M.S. pipe of 2000 mm. diameter & 22 mm thick is considered as a sleeve pipe at road crossings wherever required.  |         |
| 8     | Page no. 95 & 221  | Schedule B item No. 38 | Providing and supplying Air Valves as per IS-14845-2000 double orifice type combined with isolating sluice valve, mounted in horizontal position and operated by wheel gearing, small orifice elastic ball resting on a gun metal orifice nipple, large orifice vulcanite ball seating on moulded seat ring, inlet face and drilled, including insurance, third party inspection charges, loading, unloading, transportation upto departmental store, excluding GST levied by GOI & GOM in all respect etc. | Provision has been made for supply of air valve under item no. 16 on page no. 95. However, it does not appear that any provision has been made for the installation of the said air valve. However, it is being requested to make the necessary provision in this regard in the tender.  | The item wording shall be read as:<br><b><i>“Providing, fixing in position and commissioning high performance air release valves with isolating DI sluice valve for particle-free applications having minimum 3 functionality for air discharge, air intake and air ventilation under operation conditions. The air release valves should be designed according to EN1074 norms with fully operational against corrosion with</i></b> |         |

| Sr No | Page No.           | Ref. Clause No.        | Tender Clause  | Query raised   | MIDC's Reply  | Remarks |
|-------|--------------------|------------------------|--|--|---|---------|
|       |                    |                        |  |  | <p><b><i>GSK approval. Item includes insurance, third party inspection charges, loading, unloading, transportation upto departmental store, jointing material, nut bolts, all labour charges and giving satisfactory hydraulic test etc. complete. Manufacturer shall keep ISO 9001, ISO 14001, OHSAS 18001 certificates. In addition to those quality certificates, producer shall possess CE certificate (or equivalent). The Dynamic Air Valves shall be PN 16 of 200 mm dia."</i></b></p> |         |
| 9     | Page no. 122 & 220 | Schedule B item No. 38 | Providing of Ductile Iron D/F non-rising spindle soft seated Resilient seated butterfly Valves. Valves in accordance with BS 5163/EN 1074-1&2 of PN-10 rated, with Body and bonnet of Ductile Iron confirming to EN1563/ GGG40 Wedge fully | Provision has been made for supply of Butterfly valve under item no. 15 on page no. 122 and Provision has been made for supply of Air Valve Item No. 16 on Page No. 123. However, it does not appear that any provision has been made for the installation of the said Butterfly valve & Air Valve. However, it is | The item wording shall be read as: <b><i>"Providing, fixing in position and commissioning High-performance Ductile Iron Double Flanged Resilient Seated Butterfly Valve suitable for</i></b>  |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause  | Query raised  | MIDC's Reply  | Remarks |
|-------|----------|-----------------|--|---|---|---------|
|       |          |                 | <p>encapsulated high quality WRAS or DVGW approved EPDM rubber (approved for drinking water), Replaceable Wedge nut of Brass, Shaft of Stainless Steel EN1.4105, Stem seals min. 4 nos. of NBR, Internal fasteners of Stainless Steel A2. Replaceable Wedge nut of Brass, Shaft of Stainless Steel EN 1.4105, Stem seals min. 4 nos. of NBR, Internal fasteners of Stainless Steel A2. Body &amp; Bonnet coated inside &amp; outside with electrostatically applied epoxy powder coated blue colour RAL 5005 (suitable for drinking water) to DIN 30677-2 &amp; GSK guidelines with a coating thickness of min. 250 microns. Valves should be full bore &amp; 100% tight shut-off. Flange drilling as per IS 1538 raised face. Gate valve shall be compatible for buried applications without valve chamber. Manual operation by Handwheel. Operating torque shall be less than that</p> | <p>being requested to make the necessary provision in this regard in the tender. Also the diameter of the Butterfly Valve &amp; Air Valve is required to mention under each item.</p> | <p><i>bidirectional flow. Valve shall be according to EN593/BS 5163, the face-to-face length shall be according to EN 558-1, basic series 14/BS 5155 &amp; DIN 3202 (Long Body)/ BIS13095 (Long Body) and drilling according to EN 1092-2. Body and disc made of Ductile Cast Iron GGG-40 (EN GJS 400-15). Disc shall conform to double eccentric with Monoblock design and shall have bidirectional tightness. Valve shaft shall be made of Stainless Steel 1.4021(AISI 420). Disc and shaft components shall be equipped with Pratt &amp; Whitney Key Method. Shaft bearing bronze (Zinc free) bushes shall be self-lubricated type to reduce friction and operational torque. Bearings shall be designed to keep the</i></p> |         |

| Sr No | Page No.           | Ref. Clause No.        | Tender Clause  | Query raised   | MIDC's Reply  | Remarks |
|-------|--------------------|------------------------|--|--|---|---------|
|       |                    |                        | mentioned in EN 1171. Testing shall be as per BS 5163 / EN 12266-1&2 / IS 14846.   |  | <i>disc in centre and prevent axial movements. Item rate is inclusive of cost of supplying, Lowering, laying, Jointing in position and commissioning of butterfly Valves including cost of all Labour, jointing material, nut bolts and giving satisfactory hydraulic testing etc. complete. The Butterfly Valves shall be PN 16 of 1800 mm dia."</i> |         |
| 10    | Page no. 121 & 219 | Schedule B item No. 38 | Providing of Ductile Iron D/F non-rising spindle soft seated Resilient seated Gate Valves. Valves in accordance with BS 5163/ EN 1074-1&2 of PN-16 rated, with Body and bonnet of Ductile Iron conforming to EN1563/ GGG40 Wedge fully encapsulated high quality WRAS or DVGW approved EPDM rubber (approved for drinking water), Replaceable Wedge nut of Brass, Shaft of Stainless Steel EN1.4105, | Provision has been made for supply of Gate valve under item no. 14 on page no. 121. However, it does not appear that any provision has been made for the installation of the said Gate valve. However, it is being requested to make the necessary provision in this regard in the tender. Also the diameter of the Gate valve is required to mention. | The item wording shall be read as: <b><i>"Providing, fixing in position and commissioning Ductile Iron Resilient Seated Gate Valves, double flanged, non-rising spindle, soft seated and glandless type, suitable for potable/drinking water applications, in sizes DN 50 to DN 600 and pressure ratings PN 10, PN 16</i></b>                         |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause   | Query raised                     | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---|----------------------------------|---|---------|
|       |          |                 | Stem seals min. 4 nos. of NBR, Internal fasteners of Stainless Steel A2. Replaceable Wedge nut of Brass, Shaft of Stainless Steel EN1.4105, Stem seals min. 4 nos. of NBR, Internal fasteners of Stainless Steel A2. Body & Bonnet coated inside & outside with electrostatically applied epoxy powder coated blue colour RAL 5005 (suitable for drinking water) to DIN 30677-2 & GSK guidelines with a coating thickness of min. 250 microns. Valves should be full bore & 100% tight shut-off. Flange drilling as per IS 1538 raised face. Gate valve shall be compatible for buried applications without valve chamber. Manual operation by Handwheel. Operating torque shall be less than that mentioned in EN 1171. Testing shall be as per BS 5163 / EN 12266-1&2 / IS 14846. |                                  | <i>and PN 25. The valves shall be designed, manufactured and tested in accordance with EN 1074-1 and EN 1074-2, EN 1171 / BS 5163, with face-to-face dimensions as per EN 558-1 (Series 14 for PN10&amp; PN16 /Series 15 for PN25) and flange dimensions and drilling in accordance with EN 1092-2 for the applicable PN rating. Item rate is inclusive of cost of supplying, Lowering, laying, Jointing in position and commissioning of butterfly Valves including cost of all Labour, jointing material, nut bolts and giving satisfactory hydraulic testing etc. Complete. The Gate Valves shall be PN 16 of 450 mm dia."</i> |         |
| 11    | Page     | Scope of        | The agency shall provide  | Maps and L-sections of pipe line | The Alignment plan  |         |

| Sr No  | Page No.  | Ref. Clause No. | Tender Clause   | Query raised  | MIDC's Reply   | Remarks |
|--|-----------|-----------------|---|---|--|---------|
|  | no. 9     | work            | sufficient survey instruments such as Total station, auto level etc. along with the surveyors for operating the survey instruments and taking necessary levels and prepare L sections etc.  | are not seen to have been submitted with this tender However, it is requested to make the said maps and L-sections of pipe line available   | of the proposed pipeline is attached as per Annexure-II.   |         |
| <b>ANANTAA Engineering &amp; Infrastructures Pvt Ltd</b> |           |                 |   |   |  |         |
| 1.   | Page No.7 | Scope of Work   | An amount of Rs. 16,11,33,333/- is worked out as rebate value for dismantled MS pipes and specials. An amount of Rs.16,11,33,333/- or the amount quoted by the bidder for rebate of MS pipes and specials whichever is higher shall be deducted after commissioning of new pipeline. The dismantled M.S. pipes shall become the property of the contractor, who shall dispose of the material from the site at their own cost | Please clarify the basis on which the department arrived at the estimate of Rs. 16,11,33,333/-. Request the detailed inventory and weight calculation of the MS pipes and specials to make a competitive and realistic assessment. Please confirm if the pipes are free from all encumbrances and if any specific permits are required from local authorities for their transport and sale. The tender states the rebate will be deducted after commissioning of the new pipeline. Please clarify if this deduction will be made in a single installment from the final bill or if it will be spread across the progress bills following the dismantling phase. This clarification is essential for the bidder to manage project cash flow. | The total length of existing 1050 mm dia M.S. pipeline which can be dismantled is 16200 RM.<br><br>1.Out of this, the rebate for existing 1050 MS pipes and specials for the length of 12374 RM is Rs.5,51,92,400/-.<br><br>2.The rebate for 3826 RM length of MS pipeline is Rs.8,40,25,350/-.<br><br>3.The total rebate amount shall thus be minimum |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>Rs.13,92,17,750/-.</p> <p>The minimum amount to be quoted by the bidders for the rebate shall be Rs.13,92,17,750/-. If the bidder quotes the rebate less than Rs.13,92,17,750/-, MIDC shall revise the offer of the bidder considering minimum rebate amount of Rs.13,92,17,750/- which shall be binding on the bidders. An undertaking on Rs.500/- stamp paper shall be submitted by the bidders stating that MIDC reserves the right to revise the rebate quoted by the bidder to minimum rebate amount of Rs.13,92,17,750/- and the bidder shall not have any</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply   | Remarks |
|-------|----------|-----------------|---------------|--------------|--|---------|
|       |          |                 |               |              | <p>objection for the same. This undertaking shall be submitted by the bidders in envelope no.1 else their financial bid shall not be opened.</p> <p>Each and every weighment of dismantled pipes, specials and structural steel shall be done at the cost of the contractor in the presence of MIDC representative and all the weighment slips shall be submitted by the contractor for necessary recovery of the rebate.</p> <p>The recovery of the rebate shall be in proportion to the length of new MS pipeline laid and commissioned.</p> <p>The bidder</p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>shall visit the site of work and study the site situation very carefully and quote the amount of rebate accordingly. The amount for rebate of scrap recovered shall be the higher of following.</p> <p>i) <b>The amount quoted by the bidder for rebate of the scrap.</b></p> <p style="text-align: center;"><b>OR</b></p> <p>ii) <b>The amount based on the weight of MS pipes, specials, and structural steel dismantled at the rate of Rs. 30/- per kg for 12,374.00 RM of old pipeline and Rs. 85.50/- per kg for 3826.00 RM of new pipeline, total minimum rebate amounts Rs. 13,92,17,750/-.</b></p> |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply  | Remarks |
|-------|----------|-----------------|---------------|--------------|---|---------|
|       |          |                 |               |              | <p>The existing MS pipes, specials and structural steel shall be dismantled by the contractor after laying, jointing and commissioning the new pipeline within the stipulated contract period as per the directions of MIDC's Engineer-in-Charge and no extra time period over and above the stipulated contract period shall be granted for dismantling of existing old pipe line and specials.</p> <p>The above conditions supersede all the conditions related to the recovery of rebate on account of dismantled M.S. pipes, specials and structural steel mentioned in the</p> |         |

| Sr No | Page No.         | Ref. Clause No. | Tender Clause   | Query raised  | MIDC's Reply  | Remarks |
|-------|------------------|-----------------|---|---|---|---------|
|       |                  |                 |   |   | tender documents.<br>There are no encumbrances against any of the MS pipeline material to be dismantled. MIDC shall issue necessary gate pass / permit for disposal of the dismantled material outside the MIDC premises. |         |
| 2     | Page No.8        | Scope of Work   | Point 3: An amount of Rs.21,36,000/- is worked out for the job of dewatering. The amount of Rs.21,36,000/- or the amount quoted by the bidder whichever is less shall be paid for dewatering job. No extra claim on account of dewatering over & above Rs.21,36,000/ shall be entertained by MIDC | We request clarification on whether this cap will be increased if actual site conditions, such as unexpected high water tables or heavy rainfall during execution, require dewatering beyond the estimated scope. Since the clause states no extra claims will be entertained, we request the department to provide the working on how they have arrived this amount of Rs. 21.36L. Also we request the department to consider paying for dewatering on a "per hour" basis to ensure the contractor is fairly compensated for actual work done. | The fixed Lump-sum amount 21,36,000/- or the amount quoted by the bidder for dewatering job, whichever is less shall be paid on job basis in proportionate to the length of new MS pipeline laid and jointed.             |         |
| 3     | Page No.8/ 244 & | Scope of Work   | Contractor shall have to submit third party inspection reports for MS pipes, all  | With reference to the clause requiring the contractor to submit third-party inspection (TPI) reports  | As Per NIT.   |         |

| Sr No | Page No.                           | Ref. Clause No.                               | Tender Clause  | Query raised  | MIDC's Reply | Remarks |
|-------|------------------------------------|---|--|---|--------------|---------|
|       | 179/2<br>44<br>Point<br>8 &<br>18: |   | types of valves etc. The third-party inspection shall be carried out as per the separate Third-Party Inspection Clause enclosed in the tender document.<br>Quality Audit of the work: - Quality Audit of the work shall be carried out as per the clause And amendments included in the tender document. MIDC shall appoint third party agency Indian Institute of Technology (IIT) as a quality auditor for conducting quality audit of the work at a stage when 80% of the work is completed or at stage as decided by MIDC. The necessary expenses of quality audit shall have to be borne by the contractor. | for MS pipes and all types of valves, please clarify if the TPI agency fees and inspection charges are already included in the department's estimate or if they will be paid separately as per actuals. Since these charges vary significantly based on the agency appointed and clarify if the department will pay these charges directly to avoid any impact on the project's progress and the contractor's cash flow |              |         |
| 4     | Page No.11                         | Additional Qualification Criteria Data Sheets | The data sheets of Non Return Valves, Gate Valves/Sluice Valves, Butterfly Valves, Air Valves as per norms specified in NIT (detailed specifications) shall be stamped & signed by the original equipment  | Pls allow to submit the data sheets after entering into the contract agreement.   | As Per NIT.  |         |

| Sr No | Page No.   | Ref. Clause No.        | Tender Clause  | Query raised   | MIDC's Reply  | Remarks |
|-------|------------|------------------------|--|--|---|---------|
|       |            |                        | manufacturer (OEM) along with technical support letter from manufacture of valves which shall be submitted by the bidder in envelope no.1.   |  |   |         |
| 5     | Page No.30 | A. General             | GSTIN Registration Certificate;  | As we are not working in the state of Maharashtra, we would like to request you to permit us that, "We will be duly submitting the GST Certificate of Maharashtra once we are Lowest Bidder before entering into the contract agreement".  | As Per NIT.   |         |
| 6     | Page No.30 | A. General             | 15)The copy of valid electrical license issued by PWD GoM (applicable for electrical and mechanical works).  | Request to clarify whether this clause is applicable to this work or not. If applicable whether licence of other states is accepted or not?  | The copy of valid electrical license for this work is not required. |         |
| 7     | Page No.37 | C. Preparation of Bids | 16. Bid Security: Bid Security (E.M.D) Shall be accepted in online payment only for works costing up to Rs. 25 Cr. And for works costing more than Rs 25 Cr. the bid security will be accepted in the form of online payment/DD/B.G. | We request you to accept Insurance security bonds also as Bid Security as the Government of India, Ministry of Finance had given amendment to General Financial Rules (GFR), 2017 to include Insurance Surety Bonds as Security Instrument and also various State Governments like Tamil Nadu, Andhra Pradesh etc. across the Country are accepting Insurance security Bond as Bid security. | As Per NIT  |         |

| Sr No | Page No.    | Ref. Clause No.                   | Tender Clause  | Query raised   | MIDC's Reply | Remarks |
|-------|-------------|-----------------------------------|--|--|--------------|---------|
|       |             |                                   |  | <p>We are enclosing the following Documents for your kind reference:</p> <ol style="list-style-type: none"> <li>1. Govt. Of INDIA, Ministry of Finance – Office Memorandum</li> <li>2. Ministry of Jal Shakti, Department of Water Resources - Office memorandum Dated:10.02.2022</li> <li>3. Govt. of Andhra Pradesh, Ministry of Finance – G.O.MS.No. 94 Dated:13.11.2024</li> </ol> |              |         |
| 8     | Page no.79  | F. Special Conditions of Contract | Data Report Point 27. Secured advance for nonperishable materials brought to site. 75% of invoice value/DSR/tendered rates whichever is lowest | We request that this be modified to be based strictly on 75% of the Tendered Rates. Using the invoice value is unconventional for large-scale projects and creates administrative hurdles, so we suggest following standard government practice where the advance is calculated against the contracted rates to ensure better cash flow and consistency.                               | As Per NIT   |         |
| 9     | Page No. 44 | APPENDIX TO ITB -                 | The annual financial turn over amount is not less than Rs.65,76,21,019.12  | Please clarify whether each member of JV or JV members combined or any member of JV have to fulfil the criteria  | As Per NIT   |         |
| 10    | Page no. 44 | APPENDIX TO ITB -                 | The UNREGISTERED / REGISTERED civil contractors having registration in appropriate class with PWD,   | Please clarify whether each member of JV or JV members combined or any member of JV have to fulfil the criteria.   | As Per NIT   |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause  | Query raised | MIDC's Reply | Remarks |
|-------|----------|-----------------|--|--------------|--------------|---------|
|       |          |                 | <p>Govt. of Maharashtra / CPWD / MES / Railways / CIDCO / MJP and having experience certificate of works completed in all respects detailed as below in any Government/Semi Govt./Local bodies executed during any of last five financial years and signed by an officer not below the rank of Executive Engineer:</p> <p>A) Single work of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.8768.30 Lakhs or Single work of providing, laying and jointing M.S. water supply pipeline having length not less than 8.60 Km and having diameter not less than 900 mm.</p> <p>OR</p> <p>B) Total cost of two works of providing , laying and jointing M.S. water supply pipeline costing not less than Rs.12275.60 Lakhs or two works of providing , laying and jointing M.S. water supply</p> |              |              |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause  | Query raised | MIDC's Reply | Remarks |
|-------|----------|-----------------|--|--------------|--------------|---------|
|       |          |                 | <p>pipeline having length not less than 12.04 Km and having diameter not less than 900 mm.</p> <p>OR The UNREGISTERED / REGISTERED civil contractors having registration in appropriate class with PWD, Govt. of Maharashtra / CPWD / MES / Railways / CIDCO / MJP and having experience certificate of works completed in all respects detailed as below in any Government/Semi Govt./Local bodies executed during any of last five financial years and signed by an officer not below the rank of Executive Engineer:</p> <p>A) Single work of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.8768.30 Lakhs or Single work of providing, laying and jointing M.S. water supply pipeline having length not less than 8.60 Km and having diameter not less</p> |              |              |         |

| Sr No | Page No.   | Ref. Clause No.      | Tender Clause  | Query raised   | MIDC's Reply | Remarks |
|-------|------------|----------------------|--|--|--------------|---------|
|       |            |                      | <p>than 900 mm.<br/>OR<br/>B) Total cost of two works of providing , laying and jointing M.S. water supply pipeline costing not less than Rs.12275.60 Lakhs or two works of providing , laying and jointing M.S. water supply pipeline having length not less than 12.04 Km and having diameter not less than 900mm.<br/>OR<br/>C) Total cost of three works of providing, laying and jointing M.S. water supply pipeline costing not less than Rs.14029.25 Lakhs or three works of providing, laying and jointing M.S. water supply pipeline having length not less than 13.76 Km and having diameter not less than 900 mm.</p> |  |              |         |
| 11    | Page no.45 | APPENDIX TO ITB -    | Liquid assets and/or availability of credit facilities is 25% .  | Please clarify whether each member of JV or JV members combined or any member of JV have to fulfil the criteria. | As Per NIT.  |         |
| 12    | Page No.17 | Volume VI Section 11 | Price adjustment has been advised to consider as per   | Request to adopt the Price Adjustment formula based on   | As Per NIT.  |         |

| Sr No | Page No.        | Ref. Clause No.  | Tender Clause   | Query raised  | MIDC's Reply | Remarks |
|-------|-----------------|--|---|---|--------------|---------|
|       | 5               |  | STAR RATES  | Wholesale Price Indices (WPI) as per standard MORTH or CPWD guidelines. The Star Rate method often fails to reflect the actual market volatility of various construction inputs over the project duration; therefore, using the WPI-based formula will ensure a more transparent, balanced, and realistic compensation for price fluctuations for both the department and the contractor.   |              |         |
| 13    | Page No.17<br>7 | REGISTRATI<br>ON UNDER<br>CONTRACT<br>LABOUR<br>ACT - 1970 | While submitting the tender, the tenderer should note that he should produce the certified photo copy of Registration in prescribed form issued by Labour Commissioner... failing which no permission will be granted to continue further work under the agreement. | Regarding the requirement to provide a Maharashtra Labour Registration certificate at the time of bidding, we wish to clarify that we currently hold a valid registration under the Contract Labour Act in the state of Telangana & Andhra Pradesh. Since the tender also requires the project-specific registration to be completed within 15 days of the work order, we request the department to allow bidders from other states to submit their existing state registrations during the bidding stage, with the condition that the Maharashtra-specific registration will be obtained and submitted immediately after the contract is | As Per NIT   |         |

| Sr No                           | Page No.        | Ref. Clause No. | Tender Clause  | Query raised  | MIDC's Reply   | Remarks |
|---------------------------------|-----------------|-----------------|--|---|--|---------|
|                                 |                 |                 |  | awarded.  |  |         |
| 14                              | Page no.23<br>9 | Scheduled B     | Sl.No:10 Supply of Rubble, Murum, Sand, Soil, 60mm./40mm. metal(Hand broken), royalty charges are not included in the rates.Any revision in Royalty charges and surcharge shall be included in the rate analysis of the respective item. If there is variation in these rates the difference shall be paid extra over the items to the contractor and shall be recovered if these rates are reduced by Govt. i.e. Revenue department. The Government of Maharashtra Revenue and Forest Departments Gazette No.146 Dt. 04 June 2021 States that the Royalty charges of Rs.216.18/cum. are to be considered. The surcharge levied on Royalty shall also be payable to the contractor.<br>- Total - 47510 Cum | Request to provide the quantities of Rubble, Murum, Sand, Soil, Metal separately. | The Quantities included in the tender are as below:-<br>Rubble -1689 Cum<br>Murum -4960 Cum<br>Sand– 20 cum<br>Metal-510 cum<br>Soil-40331 cum |         |
| <b>(D) MIDC's Clarification</b> |                 |                 |  |   |  |         |

| Sr No | Page No.   | Ref. Clause No.        | Tender Clause  | Query raised | MIDC's Reply   | Remarks |
|-------|--|------------------------|--|--------------|--|---------|
| 1     | Page no. 109 & 235   | Schedule B item No. 54 | <p>Providing ISI standard R.C.C. pipes in standard lengths of following class and diameter suitable for either collar joints or rubber ring joints, excluding GST lev-ied by GOI &amp; GOM in all respect including inspection charges, transport to departmental stores, unloading and stacking etc. complete as per IS-458/1988. Note :One collar should be supplied with each full length plain ended RCC pipe, cost including in rates below. One rubber ring should be supplied with each full length of socketed pipe, cost included in rates below. Note : Only 85% rate is payable till satisfactory hydraulic testing is given.</p> | ---          | <p><i>The item wording shall be read as: "Providing ISI standard R.C.C. pipes in standard lengths of following class and diameter suitable for either collar joints or rubber ring joints, excluding GST lev-ied by GOI &amp; GOM in all respect including inspection charges, transport to departmental stores, unloading and stacking etc. complete as per IS-458/1988. Note :One collar should be supplied with each full length plain ended RCC pipe, cost including in rates below. One rubber ring should be supplied with each full length of socketed pipe, cost included in rates".</i></p> |         |
| 2     | <b><i>The items included in the schedule "B" are inclusive of all material, labour and tools &amp; equipment required to execute the item.</i></b> |                        |  |              |  |         |

| Sr No | Page No. | Ref. Clause No. | Tender Clause | Query raised | MIDC's Reply | Remarks  |
|-------|----------|-----------------|---------------|--------------|--------------|--|
|       |          |                 |               |              |              | <i>No additional payment shall be payable for execution of the items included in Schedule "B" over and above the item rate. The item rates shall be excluding GST.</i>   |
| 3     |          |                 |               |              |              | Schedule B is displayed at three locations in the tender documents. As such the "Schedule B" from page no. 86 to 141 shall be treated as cancelled. The Schedule "B" displayed from page no.212 to 239 shall be referred by the bidders. |

***Important Note: The replies to queries and clarification by MIDC as above shall form part and parcel of the tender agreement and shall be enclosed in envelope No.1 duly signed by the bidders failing which financial bid shall not be opened. The above replies and clarification shall supersede the related conditions/provisions mentioned in the tender document.***

\*\*\*\*\*

**ANNEXURE - II**

**Exist. + Prop. WTP  
@ Waluj  
Cap: 72+72 MLD**

**Prop MS RWRM  
D: 1800 mm  
L: 17.20 km**

