



No. 515-1700/SSTPP/MPPGCL/P&W/PT-3738/ T-2026_MPPGC_506486/ 1139

, Date 12.05.2026

TENDER SPECIFICATION / SCHEDULE

SUBJECT: Procurement of spares of EIP make Ash level Indicator for ESP hoppers at 2x600MW, SSTPP, MPPGCL, Dongalia.

The subject material is required as per the Technical Specification / schedule detailed here under:

TENDER SCHEDULE

Sr.	Material Description	Qty.(Nos)
1.	Sensing probe Model- 550 (Suitable for ESP) Application: ESP Hopper Process Temp: 250°C Probe length: 650mm Ingress Protection: IP66 Mounting connection: Flange type suitable for RF level switch (Flange Nozzle & nut-bolts Included)	80
2.	PCB-II(Sensor PCB)	40

Make: EIP

Note:

- 1) Firm should submit test & calibration certificate at the time of supply.

-sd-
(M Kumar)
Superintending Engineer (Purchase)
SSTPP, MPPGCL, Dongalia

Seal & Signature of Tenderer