



MADHYA PRADESH POWER TRANSMISSION CO. LTD.

(A wholly owned Govt. of Madhya Pradesh Undertaking)

CIN : U40109MP2001SGC014880, GSTIN : 23AADCM4432C1Z3

Block No.3, Shakti Bhawan, Rampur, Jabalpur (M.P.) 482008

Phone. : (0761) 270-2191, 2164, 2193, Fax - 0761-2665593 e-mail: procurement@mptransco.nic.in

No. 04-01/TR-12/2026/S-III/ACE/ 969

Date:

- 8 MAY 2026

Corrigendum-1

Sub: Procurement of FRP Discharge Rods against tender specification no. TR-12/2026 – Corrigendum thereof.

The tender specification no. TR-12/2026 has been issued for procurement of FRP Discharge Rods. The following clause of the tender document is hereby amended up to the following extent:

Sl. No.	Clause No.	Existing Clause	Amended Clause
1	4.7 – Volume-II of Tender Specification “Canvas Bags”	Water proof, heavy duty canvas bags of Red/ Orange/ Yellow colour with reinforced based having sealing strip and shoulder strap for safe storage and transportation of 01 No. complete earthing pole and associated leads (3 nos.) with their grounding copper strip and line end clamp shall be supplied for each set of Discharge Rod. Alternatively, for each set of discharge rod, two bags i.e one each for (a) Earthing poles and (b) Associated leads (3 nos.) with their grounding copper strip and line end clamps shall be supplied.	One water proof, heavy duty canvas bag of Red/ Orange/ Yellow colour with reinforced base (bottom) having sealing strip and shoulder strap for safe storage and transportation of 01 No. complete earthing pole with main fixing head, earthing cable/ lead with termination lugs, grounding copper strip and line end clamp shall be supplied for each set of discharge rod. Alternatively, for each set of discharge rod, two bags i.e one each for (a) complete earthing pole with main fixing head and (b) earthing cable/ lead with termination lugs, grounding copper strip and line end clamp shall be supplied.

The above corrigendum will be an integral part of our tender specification. All other terms and condition of the tender document will remain unchanged.


Chief Engineer (Procurement)