

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets Volume II Section-IV 220 kV GIS with GIB
---	--	--

Guaranteed Technical Particulars				
Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
1.0	220kV GIS System			
1	General			
1.1	Manufacturer	-		
1.2	Place of Manufacturer	-		
1.3	Type designation	-		
1.4	Applicable Standards	-		
2	Main data of Switchgear System			
2.1	Nominal Voltage U_n	kV		
2.2	Highest Voltage for Equipment U_m	kV		
2.3	Rated Frequency			
	· Normal Condition	Hz		
	· Exceptional Condition	Hz		
2.4	Power Frequency withstand voltage, 1 minute	kV _{rms}		
2.5	Power Frequency withstand voltage at atmospheric SF6 gas pressure			
	- continuously	kV _{rms}		
	- for 1 minute	kV _{rms}		
2.6	Lightning impulse withstand voltage			
	- against ground	kV _{peak}		
	- over isolating distance of isolators	kV _{peak}		
	- over isolating distance of circuit breakers	kV _{peak}		
2.7	Switching impulse withstand voltage			
	- against ground	kV _{peak}		
	over isolating distances of apparatus	kV _{peak}		
2.8	Maximum partial discharge of switch gear assembly at highest voltage for equipment U_m			
		pC		
2.9	Rated Continuous Current			
	- busbars and bus tie	A		
	- feeder circuits	A		
	- generator – transformer bay	A		

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets
		Volume II Section-IV
		220 kV GIS with GIB

Guaranteed Technical Particulars				
Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
2.10	Minimum symmetrical short-time withstand current, 1 second	kArms		
2.11	Minimum dynamic short-circuits withstand current	kA _{peak}		
2.12	Nominal insulating SF6 gas pressure at 20°C (minimum operating pressure)			
	- enclosures	kPa		
	- circuit breaker	kPa		
2.13	Filling SF6 gas pressure at 20°C			
	- enclosures	kPa		
	- circuit breaker	kPa		
2.14	Maximum leakage rate in percent of the respective volume, per year			
		%		
2.15	Temperature rise	°C		
2.16	Corona extinction voltage	kVrms		
3	Circuit Breaker			
3.1	· Rated continuous current	A		
	· Rated short time withstand current	kA _{peak}		
3.2	Rated symmetrical short-circuit breaking current	kArms		
3.3	Rated asymmetrical short-circuit breaking current	kArms		
3.4	Rated short-circuit making current	kA _{peak}		
3.5	Line charging current breaking capability	A		
3.6	Small inductive current breaking capability (without producing excessive over voltages)			
		A		
3.7	Number of quenching chambers	-		
3.8	Operating sequence			
	• Line breakers	-		
	• Generator feeder & tie breakers	-		
	• SST Breakers			

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets
		Volume II Section-IV
		220 kV GIS with GIB

Guaranteed Technical Particulars				
Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
3.9	Mechanical opening time	ms		
3.1	Total breaking time	ms		
3.11	Total closing time	ms		
4	Isolator			
4.1	Rated continuous current	A		
4.2	Minimum make and break capability for capacitive and magnetising current	A		
4.3	Total operating time	s		
	(closing or opening cycle)			
4.4	Temperature rise	°C		
5	Fast acting grounding switch			
5.1	Rated short-circuit making current	kA _{peak}		
5.2	Rated switching capacity			
	- inductive currents	A		
	- capacitive currents	A		
5.3	Operating times			
	- charging time of stored energy mechanism	s		
	- fast acting time	ms		
6	Safety grounding switch			
6.1	Rated short time withstand current, 1 s	kA		
6.2	Total operating time	s		
	(closing or opening cycle)			
7	Current Transformers			
7.1	Manufacturer	-		
7.2	Type designation	-		
7.3	Generator / transformer feeder CT's			
	- number of current transformers	-		
	- rated primary current / secondary current	A		
	- accuracy class/burden of core 1	-/VA		
	- accuracy class/burden of core 2	-/VA		

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets Volume II Section-IV 220 kV GIS with GIB
---	--	--

Guaranteed Technical Particulars				
Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
	- accuracy class/burden of core 3	-/VA		
	- accuracy class/burden of core 4	-/VA		
	- accuracy class/burden of core 5	-/VA		
	- accuracy class/burden of core 6	-/VA		
	- rated short-time thermal current, 1 s	kArms		
	- rated dynamic current	kA _{peak}		
	- number of CT	no		
7.4	Line Feeder CT's			
	- number of current transformers	-		
	- rated primary current / secondary current	A		
	- accuracy class/burden of core 1	-/VA		
	- accuracy class/burden of core 2	-/VA		
	- accuracy class/burden of core 3	-/VA		
	- accuracy class/burden of core 4	-/VA		
	- accuracy class/burden of core 5	-/VA		
	- accuracy class/burden of core 6	-/VA		
	- rated short-time thermal current, 1 s	kArms		
	- rated dynamic current	kA _{peak}		
7.5	Bus Coupler CT's			
	- Set-I (3 Nos.)	no		
	- rated primary current / secondary current	A		
	- accuracy class/burden of core 1	-/VA		
	- accuracy class/burden of core 2	-/VA		
	- accuracy class/burden of core 3	-/VA		
	- accuracy class/burden of core 4	-/VA		
	- accuracy class/burden of core 5	-/VA		
	- accuracy class/burden of core 6	-/VA		
7.6	SST CT's			
	- Set-I (3 Nos.)	no		
	- rated primary current / secondary current	A		
	- accuracy class/burden of core 1	-/VA		
	- accuracy class/burden of core 2	-/VA		
	- accuracy class/burden of core 3	-/VA		
	- accuracy class/burden of core 4	-/VA		

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets Volume II Section-IV 220 kV GIS with GIB
---	--	--

Guaranteed Technical Particulars				
Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
	- accuracy class/burden of core 5	-/VA		
	- accuracy class/burden of core 6	-/VA		
8	Potential Transformers			
8.1	Manufacturer	-		
8.2	Type designation	-		
8.3	Number of potential transformers	no		
8.4	Number of windings per Pt	no		
8.5	Rated transformation ratio			
	- for protection	KV/V		
	- for metering	KV/V		
8.6	Accuracy class/rated burden			
	- for protection	-/VA		
	- for metering	-/VA		
9	Surge arrester			
	- system voltage	kV		
	- rated arrestor voltage	kV		
	- rated nominal discharge	A		
	- minimum thermal capacity	-		
	- continuous operating voltage (COV)	kV		
	- MCOV as per ANSI test	kV		
	- Temporary over voltage (TOV)			
	· 1 sec	kV		
	· 10 sec			
	- One minute (dry) power frequency withstand voltage of arrestor housing	kV		
	- Impulse withstand voltage of arrestor housing with 1.2/50 ms wave	kV		
	Residual voltage with waveform 8/20 μ s at	kV		
	Discharge current of			
	1kA	kV		
	2kA	kV		
	3kA	kV		

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets
		Volume II Section-IV
		220 kV GIS with GIB

Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
	Switching surge			
	5kA	kV		
	10kA	kV		
	20 kA	kV		
	40 kA	kV		
10	Informative Data			
1	Gas system / General			
1.1	SF6 gas pressure alarm level			
	- enclosures	kPa		
	- circuit breaker	kPa		
1.2	SF6 gas processing unit			
	- make	-		
	- type	-		
	- rated capacity	1/min		
	- power supply voltage	V		
	- power consumption	kW		
1.3	Total power consumption of heating elements			
	per feeder	W		
	at supply voltage	V		
2	Circuit breaker			
2.1	Number of poles	no		
2.2	Cable charging current breaking capability	A		
2.3	Rated opening time	s		
2.4	Difference in the instants of closing / opening of contacts			
	- within a pole	s		
	- between poles	s		
2.5	Corona extinction voltage	kV		
2.6	Rated transient recovery voltage for terminal faults	kV		
2.7	Maximum dynamic forces on foundation caused by circuit breaker (3 phases)			
	- at closing, vertical forces	kN		

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets Volume II Section-IV 220 kV GIS with GIB
---	--	--

Guaranteed Technical Particulars				
Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
	- at closing, horizontal forces	kN		
	- at opening, vertical forces	kN		
	- at opening, horizontal forces	kN		
2.8	Circuit breaker operating mechanism			
	- kind of stored energy mechanism	-		
	- power consumption of charging motor	W		
	- at supply voltage	V		
2.9	Closing coil			
	- number of coils	no		
	- power consumption	W		
	- at voltage	V		
2.1	Trip coil			
	- number of coils	no		
	- power consumption	W		
	- at voltage	V		
2.11	Operating mechanism	-		
3	Isolator			
3.1	Power consumption of			
	drive motor	W		
	at voltage	V		
3.2	Mechanical terminal load	KN		
3.3	No. / details of auxiliary contacts	no.		
4	Fast acting grounding switch			
4.1	Operating mechanism			
	- kind of stored energy mechanism	-		
	- power consumption of charging motor at Voltage V	W		
	Rated short Circuit Making current			
	Rated Switching Capacity			
	Inductive Currents			
	Capacitive Currents			
	Operating Time			
	Charging Time of stored Energy Mechanism			

220KV GIS and Pothead yard of 240 MW Heo Hydro Electric Project, Arunachal Pradesh.		Technical Data Sheets
		Volume II Section-IV
		220 kV GIS with GIB

Guaranteed Technical Particulars				
Sl. No.	Description	Units	To be filled by the Bidder	Remarks (if any)
	Fast acting time			
5	Safety grounding switch			
5.1	Power consumption of driver motor at Voltage V	W		
	Rated short time withstand current (one) 1s			
	Total operating time (closing or opening cycle)			
6	Weights			
6.1	Approx. weight of one complete 3 phase feeder bay	kg		
6.2	Maximum transportation weight	kg		
7	Dimensions			
7.1	Overall dimensions of one 3-phase feeder bay			
	- length	mm		
	- width	mm		
	- height	mm		
7.2	Minimum space required for complete switchgear assembly considering requirements for testing and maintenance			
	- length	mm		
	- width	mm		
	- height	mm		