

THIS DESIGN AND DRAWING IS THE PROPERTY OF THE NUCLEAR POWER CORPORATION. IT MUST BE RETURNED WITH QUOTATION OR ORDER FOR DELIVERY OF MATERIAL OR WORKMANSHIP NOT BE MADE EXCEPT BY PERMISSION OF THE OWNER.



02 TYPICAL FLOOR PLAN
SCALE 1:100

LEGENDS:-

S.NO	SYMBOL	DESCRIPTION	QTY.
01.		HOOTER WITH STROBE	01
02.		MANUAL CALL POINT	02
03.		FIRE MAN'S TELEPHONE JACK	01
04.		SMOKE DETECTOR	04
05.		MONITOR MODULE	01
06.		FAULT ISOLATOR	01
07.		6W WALL MOUNTED SPEAKER	02
08.	-----	2CX1.5 SQ.MM Cu. HFFR WIRE IN PVC CONDUIT	
09.	-----	2CX1.5 SQ.MM Cu. HFFR WIRE IN PVC CONDUIT FOR FIRE PHONE JACK	
10.	-----	2CX1.5 SQ.MM Cu. FIRE RETARDANT INSULATED WIRE IN PVC CONDUIT FOR SPEAKER CABLE	

GENERAL NOTES:

- * ALL DIMENSIONS ARE IN MILLIMETERS, LEVELS IN METER. ALL DIMENSIONS ARE TO BE READ AND NOT MEASURED.
- * ANY/ ALL DISCREPANCIES MUST BE BROUGHT TO THE NOTICE OF THE CONSULTANT BEFORE PROCUREMENT/ EXECUTION OF WORK AT SITE.
- * THIS DRAWING MUST BE READ IN CONJUNCTION WITH ALL RELEVANT ARCHITECTURAL, STRUCTURAL, PLUMBING, FIRE FIGHTING, ELECTRICAL LAYOUTS AND RELATED SHOP-DRAWINGS.
- * ALL WALLS ARE ALIGNED TO FACE OF CONCRETE COLUMNS OR ARE ON CENTERLINE OF GRIDS UNLESS NOTED OTHERWISE.
- * ALL CIVIL WORKS AROUND/IN MEP AREAS SHALL BE CONSTRUCTED AS PER MEP CONSULTANT DETAILS & REQUIREMENT, AND SHALL BE CONSTRUCTED POST MEP SERVICES INSTALLATION/COMMISSIONING.
- * ALL FINISHES/LAYOUT OF LIFT-CORE, LOBBY, LOBBY TOILET, ETC. SHALL BE AS PER DESIGN DETAIL.
- * ALL SPARE SHAFT/UNUTILIZED OUTOUTS OF SHAFTS SHALL BE FIRE-SEALED.
- * LIFT DOORS JAMB/WALLS/LINTELS SHALL BE EXECUTED ONLY UPON FINALIZATION OF LIFT SHOP DRAWINGS.
- * FFL, FGL, ETC. LEVELS MENTIONED ARE TO BE READ WITH REFERENCE FROM CONTIGUOUS DRIVEWAY. BLOCK DRIVEWAY LEVELS ARE TO BE REFERRED FROM SITE SETTING-OUT PLAN.

R2	06.03.2026	ISSUED FOR COMMENTS/APPROVAL	
R1	25.02.2026	ISSUED FOR COMMENTS/APPROVAL	
R0	13.10.2025	ISSUED FOR COMMENTS/APPROVAL	

REV.	DATE	REVISION NOTE
------	------	---------------



REVIEWED:	APPROVED:
NAME:	NAME:
DATE:	DATE:

DRAWING NO. (NPCIL INTERNAL DWG. NO.) KAIGA-1-6/91214/5001/ELV/R0	REVISION NO. R0
--	--------------------

ARCHITECT:

VYOM
ARCHITECTS & ENGINEERS
E-147, OKHLA PHASE-3, NEW DELHI 110020.
T: +91 11 2691 0018 / 0019
E: INFO@VYOM.IN W: WWW.VYOM.IN

TITLE :- FIRE ALARM & PA SYSTEM LAYOUT
TYPE-D SPECIAL (TYPICAL FLOOR)

DES'D. DATE	DR'N. DATE	SS 06/03/2026	REV'D. DATE	AD 06/03/2026
DES. CHK'D. DATE	DRG. CHK'D. DATE	AD 06/03/2026	APP'D. DATE	AD 06/03/2026

PROJECT	KAIGA-5&6 TOWNSHIP	SCALE	1:125
		PROJECTION	

DRG. No. NPCL-KAGA-WD-ELV-DSP-110	REV. No. R2
-----------------------------------	----------------

FLOPPY/CD No.	FILE NAME: TYPE-D SPECIAL
DRG. TO BE READ IN CONJUNCTION WITH DCN/FCN/ECN, IF ANY.	

No.	LOCATION	DESCRIPTION	DR'N.	DES'D.	D.CHK'D.	REV'D.	APP'D.
R2		ISSUED FOR COMMENTS/APPROVAL	SS	SS	AD	AD	AD
R1		ISSUED FOR COMMENTS/APPROVAL	SS	SS	AD	AD	AD
R0		ISSUED FOR COMMENTS/APPROVAL	IA	IA	AD	AD	AD