

Minutes of pre bid meeting of the Committee for the work Augmentation and up gradation of 66/11KV grid substation at PGIMER, Chandigarh held on 05.05.2026 at 11.00 A.M in the Committee Room, S.H.E. office under the chairmanship of Prof. Arun Aggarwal, P.I (Engg).

The following attended the meeting:

1. Hospital Engineer (Electrical), Convener
2. Hospital Engineer (Planning) or Representative
3. Assistant Engineer (Elect-I & Plg.)

Two agencies i.e M/S Rajson Electrons and M/S Hartek submitted the written queries before and on the day of Pre bid meeting. The queries were deliberated and decided as below:


A. M/S Rajson Electrons


S.No	Queries	DNIT condition	Reply
1	Regarding GST inclusion: Are the estimated rates provided in the tender inclusive of GST or exclusive of GST? If the rates are inclusive of GST, then the estimated cost for this work appears to be undervalued. Considering the current market prices for 66/11KV substation equipment (e.g. Transformers, switchgears) and the required technical specifications the provided rates do not seem technically or economically viable.	Rates are inclusive of all taxes.	No change from the DNIT condition.
2	Technical suggestion for item no. 22 (Earthing) "We observed that the current specification for earthing in item no. 22 of the BOQ -40mm GI pipe earthing, instead of this we are suggesting that replacing the existing earthing specification with 150mm diameter CI (Cast Iron) pipe of 3 meters length.	DSR CPWD earthing.	No change from the DNIT condition.


B. M/S Hartek Power Private Limited


1	BOQ item no. 25 - 11KV HT Cable: The unit mentioned as Mt. should be corrected to Mtr.		May be read as Mtr instead of MT
2	BOQ item no. 33 - structure: The unit mentioned as Mtr should be corrected to MT.		May be read as MT instead of Mtr

The meeting ended with vote of thanks to the Chair.


Assistant Engineer (Plg)
Rep. of H.E (Plg.)


Assistant Engineer
(Elect-I & Plg)


Hospital Engineer
(Electrical)


Prof. Arun Aggarwal, P.I (Engg)
Chairman